

TO: Ms. Kate Collins,

Planning Board Chair Town of Royalston

Town Hall on the Common

Royalston, MA 01368

(978)249-4407

FROM: Gina Wolfman, Senior Developer

DATE: December 3, 2018

RE: Special Permit Application Package for a Ground Mounted Solar Project; 4 Bel

Nel Road & 4 King Street

Enclosed you will find seven (7) copies of the Special Permit Application (attached after application checklist), with supporting documentation, for a proposed large scale, ground-mounted, solar photovoltaic project. We would like to be placed on the agenda for the December 11 Planning Board meeting.

We understand there is a peer/third party review process and applicant is required to cover the cost of such review, along with fees for abutters' notifications, certified abutters list, and public hearing notices. The drawing sets (7) will be sent to you directly under separate cover from the civil engineer, SWCA Environmental Consultants in Amherst, MA.

If you have any questions, I can be reached at: 860-398-5408 x328 or via email at: gina.wolfman@cleanfocus.us.

Thank you.



December 3, 2018

#### Clean Focus Renewables & Greenskies Renewable Energy

Special Permit Application for Commercial Ground-Mounted Solar Project at 4 Bel Nel Road & 4 King Street, Royalston, MA

Developer & Installer Contact:

Gina Wolfman
Greenskies, A Clean Focus Company
180 Johnson Street
Middletown, CT 06457
(860) 398-5408 x328
gina.wolfman@cleanfocus.us

Clean Focus Renewables, Inc. 150 Mathilda Place, Suite 206 Sunnyvale, CA 94086

<sup>\*\*</sup>Permit/Site Plan drawing set will be submitted under separate cover from civil engineer, SWCA Environmental Consultants (Amherst, MA)



**Royalston Planning Board Submission Checklist** 

Status	Submission Requirement	Notes
Included	Special Permit Application	7 copies of application and plans/package
	SOLAR BYLAW REQUIREMENTS	
Included	Plans and drawings of the solar energy facility signed and stamped by a P.E. licensed in Massachusetts showing the proposed layout of the system	
Included	Electrical Drawing: An electrical diagram detailing the solar energy facility, associated components, and electrical interconnection methods, with all National Electrical Code compliant disconnects and over current devices	
Included	Technical Documentation: specifications of the major system components, including the solar arrays, mounting system, and inverter	Equipment specifications attached
Included	Contact Info: The name, address, and contact information of the owner, proposed installer, and operator	
Included	Site Control: Proof of actual or proposed control of access ways and the project site sufficient to allow for installation and use of the proposed facility	Executed lease attached
Included	Zoning map: zoning district designation for the parcel(s) of land comprising the project site (submission of a copy of a zoning map with the parcel(s) identified is suitable for this purpose)	Attached
Included	O & M Plan: Measures for maintaining safe access, storm water controls, and general procedures for operating and maintaining the energy facility	O & M Plan and overview attached
Included	Proof of liability insurance	Certificate of Insurance Attached
Included	Financial Surety: Surety shall be submitted to the Planning Board/Building Inspector at time of application and shall be approved before special permit/building permit is issued.	Description of Financial Surety attached for approval
Included	Utility Notification: The applicant shall submit evidence satisfactory to the Planning Board that he has informed the utility company in writing of his intent to install a solar energy facility	Excerpts from Interconnection Application attached
	SITE PLAN REQUIREMENTS	
Included	Property lines and physical features, including roads, for the project site;	
Included		
Included	Drawings of the solar photovoltaic installation signed by a Professional Engineer licensed to practice in the Commonwealth of Massachusetts showing proposed layout of the system and any potential shading from nearby structures.	
Included	One or three line electrical diagrams detailing the solar photovoltaic installation, associated components, and electrical interconnection methods, with National Electrical Code compliant disconnects and overcurrent devices	Attached as 11" x 17" plan set



Status	Submission Requirement	Notes
Included	Documentation of the major system components to be used, including the PV panels, mounting system, and inverter	
Included	Name, address, and contact information for proposed system installer	
Included	Name, address, phone number and signature of the project proponent, as well as all co-proponents or property owners, if any	
Included	The name, contact information and signature of any agents representing the project proponent;	
	DESIGN STANDARDS	
Included	Dimension and Density Requirements. Large Scale Solar Energy Systems shall comply with all standards within Intensity Requirements section of the Zoning Bylaw	
Included	Lighting shall be consistent any state and federal law. Lighting of the installation shall be limited to that required for safety and operational purposes, and shall be reasonably shielded from abutting properties. Where feasible, lighting shall be directed downward and shall incorporate full cut-off fixtures to reduce light pollution.	
Included	Signage. Solar photovoltaic installations shall not be used for displaying any advertising except for reasonable identification of the manufacturer or operator of the solar photovoltaic installation	
Included	Screening/ Buffer Requirement. If permitted by special permit in residential districts, the entire perimeter of the project shall have a vegetated buffer that will screen the view of the installation, sufficiently dense to block the view of the facility from all dwellings abutting the property. In all other districts where site plan approval is given, the project shall have a vegetative buffer that will screen the view of the installation from the boundary of any abutting residential premises and from the boundary of an abutting residential district and/or farm and forest district.	
Included	Utility Connections. Reasonable efforts, as determined by the Planning Board, shall be made to place all utility connections from the installation underground, depending on appropriate soil conditions, shape, and topography of the site and any requirements of the utility provider. Transformers for utility interconnections may be above ground if required by the utility provider.	
	SAFETY, EMERGENCY AND ENVIRONMENTAL STAND	DARDS
To be provided	Emergency Services. Owner or operator shall provide a copy of the project summary, electrical schematic, and site plan to the fire chief. Owner or operator shall cooperate with local emergency services in developing an emergency response plan. All means of shutting down the solar photovoltaic installation shall be clearly marked. The owner or operator shall identify a responsible person for public inquiries throughout the life of the installation.	
Included	Land Clearing, Soil Erosion and Habitat Impacts. Clearing of natural vegetation shall be limited to what is necessary for the construction, operation and maintenance of the large – scale ground-mounted solar photovoltaic installation. The applicant will implement Best Management Practices (BMPs) to help manage stormwater per the Zoning Bylaw requirements for Low Impact Development.	



## **Planning Board/Special Permit Application**



#### The Commonwealth of Massachusetts

#### TOWN OF ROYALSTON PLANNING BOARD P.O. Box 125 Royalston, MA 01368

#### SPECIAL PERMIT APPLICATION

		51	ECIAL	I LICOTTI TO	LICA	
1. SPEC	CIAL PERM	IIT NOTICE OI	F FILING	<u>i TO</u> :		
ROYALS	STON TOV	VN CLERK	a	and		I OF ROYALSTON NING BOARD
DATE: _	December	3, 2018				
NAME C	F OWNER	/ APPLICANT:	:			
Clean F	ocus Renew	ables/Greenskie	es Renewa	able Energy		
MAIL AI	DDRESS:_	180 Johnson Str	eet, Midd	lletown, CT (	06457	TEL: _860-398-5408 X 328
ATTENT	TION TOW	N CLERK AND	) PLANN	IING BOARI	Э;	
Applicati	on, to be fil	, pursuant to Ge led with Town ( date)_December	Clerk on (d	date) Decen	ber 5, 2	ave an Special Permit 2018 and the Royalston ase verify this Date with the Planning
Numb	per) to read	ily identify land	or buildir	ng which is the	ne subjec	t description (Map and Parcel et of this application.) 5/017.0-0002-0000.0
4 King	Street; Map	022.0, Block 00	10, Lot 00	000.0; Parcel	ID: 255/0	022.0-0010-0000.0
List each County R Derek I	name exac Registry of I D. & Sheena	tly as it appears Deeds. Please h	in the dee ave availa l Nel Road	ed or petition able such dee d, Royalston,	and the d or a co	eed 51646, p. 194
BOOK:	51646 36378		PAGE:	194 391		

4. State the name, mailing address and telephone number of each attorney, agent, or other representative of the applicant(s).					
5. TOWN ZONING BYLAW DESIGNATION					
The undersigned hereby appeals to the Royalston Planning Board for a Special Permit (Royalston Zoning Bylaw Section V.A.) to conduct a business/project in one of the Zoning Districts outlined in the Town of Royalston By-Laws as follows: (Please check applicable use)					
<ul> <li>( X) Large Solar Installations 40 kW or greater (Royalston Zoning Bylaw Section VIII.B)</li> <li>( ) Utilities greater than 40 kW</li> <li>( ) Accessory Major Home Occupations (Royalston Zoning Bylaw Section III.E.4.b)</li> <li>( ) Telecommunications &amp; Wireless Towers (Royalston Zoning Bylaw Section VIII.A)</li> <li>( ) Accessory Fixed Wireless Broadband Facilities over ten (10) feet in height</li> <li>( ) Large Wind Energy System (LWES): (80) eighty feet and over in height</li> </ul>					
PROJECT/BUSINESS DESCRIPTION:  See attached site plan set for visual description of proposed work. Clean Focus Renewables/Greenskies Renewable Energy wishes to install, own, operate and maintain a large, ground-mounted solar array at 4 Bel Nel Road and 4 King Street, with proposed access from an existing gravel access road off King Street. No portion of the array will be installed within wetland resource areas or setback/buffer areas. A Request for Determination of Applicability (RDA) was submitted to the Conservation Commission on November 30, 2013 The properties are mostly forested with areas of cleared land and former agricultural fields. Both lots have residential homes and out-buildings along frontage. There is no 100-year flood zone on the property, no perennial streams and no Riverfront Area. Wetlands identified on-site include Bordering Vegetated Wetland containing Bank and an Isolated Vegetated Wetland.					
Gina L. Wolfman  Date: December 4, 2018  Signature of Applicant					
Royalston Town Clerk Signature  Date:					
Planning Board Clerk Signature or Representative					

A Pre-application meeting with the Planning Board is encouraged to help facilitate the Special Permit Process. Please contact to reserve a spot on the Planning Board's Agenda.					
Please be advised that the Special Permit Applicant will be responsible for costs related to processing the Special Permit; including abutter's notification, abutter's list, and public hearing notices.					
FOR YOUR MEETING WITH THE PLANNING BOARD, INCLUDE THE FOLLOWING:					
<ol> <li>Plans date stamped by the Town Clerk</li> <li>Abutters list</li> <li>Application/Notice of Filing signed and date stamped by the Town Clerk</li> </ol>					
3. Application/Notice of Filing signed and date stamped by the Town Clerk					

Form Accepted Date



### Documentation/Specification Sheets of Major System Components

## **EQUIPMENT DATA SHEETS**





## D6M\_B4A 330W - 365W

Mono-Crystalline Photovoltaic Module



Positive power tolerance 0~+4.99 watt



Withstand strong snow load 5400 Pa / wind load 2400 Pa



Excellent low light performance 3.5% relative eff. reduction at low-irradiance (200W/m²)



100% EL inline inspection Better module reliability



Prolonged aging test 2000 hours damp heat test; 400 thermal cycles



Ammonia resistance According to IEC 62716 Ed. 1














#### - Reliability & Certification

Product guarantee: 10-year Linear Performance Warranty - 1-year: 97% power output

then power degradation 0.7% per year till 25th year

- 25-year: 80.2% power output
- 10-year: 90.7% power output
UL 1703, CEC, IEC 61215/IEC 61730, CE, MCS

\* Please refer to NSP product warranty for details



For more information, please visit us at www.nsp.com



#### **Electrical Data**

DAM	DEM	DEM	D6M	D6M	D6M	D6M	D6M
330 84A	335 84A	340 84A	345 B4A	350 B4A	355 84A	360 B4A	365 B4A
330 W	335 W	340 W	345 W	350 W	355 W	360 W	365 W
17.0%	17.3%	17.5%	17.8%	18.0%	18.3%	18.6%	18.8%
45.92 V	46.04 V	46.16 V	46.61 V	46.89 V	47.16 V	47.44 V	47.67 V
37.38 V	37.47 V	37.57 V	37.96 V	38.34 V	38.63 V	39.01 V	39.38 V
9.32 A	9.41 A	9.48 A	9.51 A	9.54 A	9.70 A	9.77 A	9.84 A
8.85 A	8.96 A	9.06 A	9.09 A	9.13 A	9.19 A	9.23 A	9.27 A
	330 W 17.0% 45.92 V 37.38 V 9.32 A	330 335 84A 84A 330 W 335 W 17.0% 17.3% 45.92 V 46.04 V 37.38 V 37.47 V 9.32 A 9.41 A	330 335 340 84A 84A 84A 330 W 335 W 340 W 17.0% 17.3% 17.5% 45.92 V 46.04 V 46.16 V 37.38 V 37.47 V 37.57 V 9.32 A 9.41 A 9.48 A	330         335         340         345           84A         84A         84A         84A           330 W         335 W         340 W         345 W           17.0%         17.3%         17.5%         17.8%           45.92 V         46.04 V         46.16 V         46.61 V           37.38 V         37.47 V         37.57 V         37.96 V           9.32 A         9.41 A         9.48 A         9.51 A	330         335         340         345         350           84A         84A         84A         84A         84A           330 W         335 W         340 W         345 W         350 W           17.0%         17.3%         17.5%         17.8%         18.0%           45.92 V         46.04 V         46.16 V         46.61 V         46.89 V           37.38 V         37.47 V         37.57 V         37.96 V         38.34 V           9.32 A         9.41 A         9.48 A         9.51 A         9.54 A	330         335         340         345         350         355           84A         84A         84A         84A         84A         84A           330 W         335 W         340 W         345 W         350 W         355 W           17.0%         17.3%         17.5%         17.8%         18.0%         18.3%           45.92 V         46.04 V         46.16 V         46.61 V         46.89 V         47.16 V           37.38 V         37.47 V         37.57 V         37.96 V         38.34 V         38.63 V           9.32 A         9.41 A         9.48 A         9.51 A         9.54 A         9.70 A	330         335         340         345         350         355         360           84A         84A         84A         84A         84A         84A         84A         84A           330 W         335 W         340 W         345 W         350 W         355 W         360 W           17.0%         17.3%         17.5%         17.8%         18.0%         18.3%         18.6%           45.92 V         46.04 V         46.16 V         46.61 V         46.89 V         47.16 V         47.44 V           37.38 V         37.47 V         37.57 V         37.96 V         38.34 V         38.63 V         39.01 V           9.32 A         9.41 A         9.48 A         9.51 A         9.54 A         9.70 A         9.77 A

<sup>\*</sup>Electrical data under Standard Test Conditions (STC): Cell Temperature of 25 °C, Irradiance 1000 W/m², AM 1.5

#### **Mechanical Data**

Item	Specification
Dimension	1956mm (L) <sup>1</sup> x 992 mm (W) <sup>1</sup> x 35 mm (D) <sup>2</sup> / 77" (L) <sup>1</sup> x 39.1" (W) <sup>1</sup> x 1.38" (D) <sup>2</sup>
Weight	23 kg / 50.7 lbs
Solar Cell	72 monocrystalline 6" silicon cells
Front Glass	Anti-reflective tempered solar glass, 3.2 mm thickness
Cell Encapsulation	EVA (Ethylene-Vinyl-Acetate)
Back Cover	Composite film, white
Junction Box	IP 67 rated
Frame	Anodized aluminum frame, original or black
Packaging Configuration	30 pcs Per Pallet, 660pcs Per 40' HQ container
1 : With assembly tolerance of ± 2 m 2 : With assembly tolerance of ± 0.8	m [± 0.08"] mm [± 0.08"]

#### **Operating Conditions**


Item	Specification
Mechanical Load	5400 Pa (Certified by TÜV Rheinland)
Maximum System Voltage	1000 VDC
Series Fuse Rating	15 A
Operating Temperature	-40 to 85 °C


#### **Temperature Characteristics**

Item	Specification
Nominal Operating Cell Temperature	44 °C ± 2°C
Temperature Coefficient of Isc	0.042 % / °C
Temperature Coefficient of Voc	-0.318 % / °C
Temperature Coefficient of Pmax	-0.427 % / °C


- Nominal Operating Cell Temperature (NOCT): Irradiance 800W/m², Ambient Temperature 20 °C, Wind Speed 1 m/s
   Please refer to NSP's Standard Module Installation Manual before using the product
   Reduction in efficiency from 1000 W/m² to 200 W/m² at 25 °C: 3.5% ± 2 %

#### Front View & Back View





#### Dependence on Irradiance



#### **Contact Us**

#### **Neo Solar Power Corporation**

Headquarters: 7, Li-Hsin 3rd Rd., Hsinchu Science Park, Hsinchu, 30078, Taiwan

Tel: +886-3-578-0011 Fax: +886-3-578-1255 www.nsp.com

Email: sales.module@nsp.com Website: www.nsp.com

<sup>\*</sup>Values w/o tolerance are typical numbers \*Specifications subject to change

## Re-defining the utility-scale inverter

#### Conext SmartGen™

We believe in green energy—in the ability to meet and contribute to growing power demand while supporting a smart grid that serves a smart society.



#### Solution at a glance

Far more than an inverter, the Conext SmartGen™ is the new paradigm for large-scale renewable power installations. It combines the best in power conversion technology with the Industrial Internet of Things to provide a better Levelized Cost of Energy.

- More power generation and longer service life: 30+ year service life and conversion efficiency of 98.8% peak, 98.5% EU
- Lower OPEX: True Design for Service™ and cloud-connectivity for fewer and faster resolution of service events
- Higher system availability: fewer failures with predictive maintenance and faster time to repair with enhanced remote troubleshooting
- Deploy everywhere: designed and tested for any environment, NA and IEC codes and standards, and supported by a worldwide field service network
- Secure: backed by a bankable company with 180 years of history and two decades of experience in solar inverters

Global specialist in energy management

160,000+ total workforce in 100+ countries 180 years of history

5% of Group revenues devoted to annual R&D spend

#### True Bankability with Schneider Electric

€27 billion in consolidated revenue

€2.1 billion adjusted net income

More than 7 GW of Schneider Electric utility-scale inverters installed worldwide

## Reliable and cloud-connected

Conext SmartGen

#### Lifetime reliability

Through the most stringent selection and qualification of components, the Conext SmartGen™ is designed to have a 30-year lifespan with just one major preventive maintenance at mid-life in worst case conditions.

The most demanding reliability and environmental testing methodology, developed through 20 years experience in the PV industry, has been applied to ensure that the Conext SmartGen™ maintains adequate operating margins over its entire lifetime, in even the most severe environments.



Desert



Ocean





(d cx sh · G in

Continental

Tropical

- Built to last in the most severe environments (desert, tropical, continental, sea shore, high seismic)
- Greater uptime for increased power generation

#### True Design for Service™

Ease of service was the driving force behind big and small decisions that shaped the Conext SmartGen™.

From a comprehensive suite of diagnostics, troubleshooting and maintenance tools to quickly replaceable sub-assemblies, every step of servicing has been meticulously optimized to minimize operating expenses.





- Designed for one hour mean time to repair and first time fix rate >97%
- · Advanced configuration and service tool with full local and remote functionality
- · Immediate access to all field replaceable systems and components

#### Predictive maintenance

Advanced predictive maintenance algorithms running in the Conext™ PowerCloud enable remaining lifetime estimation of major components, as well as failure prediction.



- Predict when components or systems may fail, ensuring they can be replaced just in time (not too early, and not too late)
- Reduce and defer maintenance costs by making decisions based on actual operating conditions

#### Local and remote interface - the Conext Viewer™

The most advanced inverter interface yet, providing local Wi-Fi and Ethernet connectivity as well as remote data access to inverter operational data.

Advanced troubleshooting, lifetime service logging, remote firmware upgrades, online service documentation and help files—all the power and capabilities of the digital world supporting your Conext SmartGen\* inverter.

- · Reduced learning curve that increases user satisfaction and minimizes risks
- Incorporated help mechanism that enables service personnel to do fast and accurate troubleshooting



Conext SmartGen

#### IEC and NA versions

- NA version includes optional NEC compliant DC disconnect switches
- → Reduced footprint
- → Easier fuse servicing

#### Multiple grounding options

- · Floating with permanent insulation monitoring
- Negative grounding with pre-connection insulation check, and RCD
- → Enhanced personnel and equipment safety





#### Class I surge arrestors

- · Selectable on DC and AC
- → Enhanced protection against lightning strikes

#### Integrated communications and control panel

- · Modbus RTU and Modbus TCP
- · Optional communications hub for all skid mounted and field equipment
- Conext™Advisor 2 Programmable Logic Controller for fast controls of ES inverters
- · Copper or fiber optic switch options available for the communications hub
- → Allows for integrated monitoring and control hardware

#### Auxiliary power distribution panel

- · Selection of auxiliary AC voltage (100/110/120/200/220/230/240V)
- · Input circuit breaker with under voltage release
- · Auxiliary consumption metering
- → Elimination of external low voltage panel

#### Varied DC input configurations

- · 10 to 14 inputs with 160 to 400A fusing
- · Input channel current monitoring
- → Wide range of overpaneling ratio

## Product specifications

Conext SmartGen

Device short name	CS1800	CS2000	CS2200		
Electrical specifications					
AC					
Nominal output power at 40°C	1800 kW / 2000 kVA	2000 kW / 2000 kVA	2200 kW / 2200 kVA		
Nominal output power at 50°C	1800 kW / 2000 kVA	2000 kW / 2000 kVA	2060 kW / 2060 kVA		
Nominal output voltage	575 V	575 V	600 V		
Nominal frequency	50 / 60 Hz	50 / 60 Hz	50 / 60 Hz		
Max. output current	2008 A	2008 A	2117 A		
Continuous operation output voltage range	+/- 20% (460 - 690 V)	+/- 20% (460 - 690 V)	+15% / -20% (480 - 690 V)		
Continuous operation frequency range	50 / 60 Hz +/- 10%	50 / 60 Hz +/- 10%	50 / 60 Hz +/- 10%		
Power factor'	0 to 1 lead / lag	0 to 1 lead / lag	0 to 1 lead / lag		
Harmonic distortion (THDI)	< 3% at rated power	< 3% at rated power	< 3% at rated power		
Peak efficiency	98.8%	98.8%	98.8%		
Weighted efficiency (EU weightings)'	98.5%	98.5%	98.5%		
Weighted efficiency (CEC) <sup>3</sup>	98.5%	98.5%	98.5%		
DC					
Max. input voltage range, MPPT*	865 - 1500 V	865 - 1500 V	905 - 1500 V		
Max. input voltage, open circuit	1500 V	1500 V	1500 V		
Max. input operating current	2123 A	2359 A	2481 A		
DC breaker short-circuit current rating	6000 A	6000 A	6000 A		
Max. rated short circuit current		A fuse rating: 3584 A STC, 4480 A ab			
DC combiner	Integrated	Integrated	Integrated		
Number of DC inputs	10 to 14	10 to 14	10 to 14		
DC fuse rating	160 A - 400 A	160 A - 400 A	160 A - 400 A		
General specifications					
Service life <sup>5</sup>	30 years				
Power consumption, night time <sup>6</sup>	< 295 W				
Degree of protection 7	Outdoor (Type 4X / IP65)				
Enclosure					
Enclosure	Aluminium	high salamia ausfarmanaa lavala (70	00 = 1 0 = 20/ domn(n n)		
Seismic rating		high seismic performance levels (ZP fication to a SDS equal to 1.78g and v	/A = 1.0g 2% damping) with a z/h equal to 0 and IP=1.5 UBC Zone		
Product weight (approx.)	2800 kg (6160 lb)				
Product dimensions (H x W x D)	220 x 300 x 130 cm (86.6 x 11	8.1 x 51.2 in)			
Ambient air temperature for operation	-30°C to 60°C (-22°F to 140°F)	Programme and the second			
Operating altitude	2,000 m without derating, up t	o 4,000 m with derating			
Relative humidity	5% to 100% condensing				
Features					
Type of cooling	Temperature-dependent low p	pressure closed-loop liquid cooling			
Graphic user interface	Conext™ Viewer application fo	r tablet and PC			
External communication interface	Modbus/RS485 standard, Modbus/TCP				
AC/DC disconnect	Load-break-rated DC and AC circuit breaker standard				
Ground fault detection/interruption	PV insulation monitoring and I	RCD (on grounded PV configurations)			
Options					
	Grounding (negative / floating	), string current monitoring, class I su	irge arresters		
Standards					
Safety standards	IEC version: IEC62109-1, and	-2 / NA version: UL 1741, CSA 107.1			
baidty standards					
EMC standards		N 55011:2016, CISPR 11 Ed. 6, FCC C	Class A		

Contact Schneider Electric for derating information.

'Auxiliary self consumption not included, measured at minimum Vdc.

'Auxiliary self consumption included,

'Contact Schneider Electric for derating information, MPPT for Power Factor 1.

With preventative maintenance.

295 W maximum is with all communication hub options.

'Heat exchanger is IP20 with IP65 components.

## Product specifications

Conext SmartGen

Device short name	CS1666-1-NA	CS1666-2-NA	CS1666-3-NA		
Electrical specifications					
AC	-				
Nominal output power at 50°C	1666 kW / 1666 kVA	1666 kW / 1831 kVA	1666 kW / 1851 kVA		
Nominal output voltage	575 V	575 V	575 V		
Nominal frequency	50 / 60 Hz	50 / 60 Hz	50 / 60 Hz		
Max. output current	1673 A	1838 A	1859 A		
Continuous operation output voltage range	+/- 20% (460 - 690 V)	+/- 20% (460 - 690 V)	+/- 20% (460 - 690 V)		
Continuous operation frequency range	50 / 60 Hz +/- 10%	50 / 60 Hz +/- 10%	50 / 60 Hz +/- 10%		
Power factor	0 to 1 lead / lag	0 to 1 lead / lag	0 to 1 lead / lag		
Harmonic distortion (THDI)	<3% at rated power	<3% at rated power	<3% at rated power		
Peak efficiency	98.8%	98.8%	98.8%		
Weighted efficiency (CEC) <sup>3</sup>	98.5%	98.5%	98.5%		
DC					
Max. input voltage range, MPPT	865 V - 1500 V	865 V - 1500 V	865 V - 1500 V		
Max. input voltage, open circuit	1500 V	1500 V	1500 V		
Max, input operating current	1965 A	1965 A	1965 A		
DC breaker short-circuit current rating	6000 A	6000 A	6000 A		
Max. rated short circuit current	With max. 14 DC inputs x 400	A fuse rating: 3584 A STC, 4480 A	A absolute max.		
DC combiner	Integrated	Integrated	Integrated		
Number of DC inputs	10 to 14	10 to 14	10 to 14		
DC fuse rating	160 A - 400 A	160 A - 400 A	160 A - 400 A		
General specifications					
Service life <sup>4</sup>	30 years				
Power consumption, night time*	295 W				
Degree of protection	Outdoor (Type 4X)				
Enclosure	Aluminium				
Seismic rating	Zone 4 per UBC				
Product weight (approx.)	2800 kg (6160 lb)				
Product dimensions (H x W x D)	220 x 300 x 130 cm (86.6 x 118.1 x 51.2 in)				
Ambient air temperature for operation	-30°C to 60°C (-22°F to 140°F	-)			
Operating altitude	2,000 m without derating, up	to 4,000 m with derating			
Relative humidity	5% to 100% condensing				
Features					
Type of cooling	Temperature-dependent low	pressure closed-loop liquid coolin	g		
Graphic user interface	Conext™ Viewer application f	Conext™ Viewer application for tablet and PC			
External communication interface	Modbus/RS485 standard, Modbus/TCP				
AC/DC disconnect	Load-break-rated DC and AC circuit breaker standard				
Ground fault detection/interruption	PV insulation monitoring and	RCD (on grounded PV configuration	ions)		
Options					
	Grounding (negative / floatin	g), string current monitoring, class	1 surge arrestors		
Standards					
Safety standards	UL 1741, CSA 107.1				
EMC standards	FCC Class A				
Grid interconnection	IEEE 1547 and 1547a				

Contact Schneider Electric for derating information.

'Auxiliary self consumption not included, measured at minimum Vdc,
'Auxiliary self consumption included.

Contact Schneider Electric for derating information, MPPT for Power Factor 1.

With preventative maintenance, 295 W maximum is with all communication hub options,

Life Is On Schneider

# Re-defining the utility-scale inverter

#### Conext SmartGen™

We believe in green energy—in the ability to meet and contribute to growing power demands while supporting a smart grid that serves a smart society.



#### Solution at a glance

Far more than an inverter, the Conext SmartGen™ is the new paradigm for large-scale renewable power installations. It combines the best in power conversion technology with the Industrial Internet of Things to provide a better Levelized Cost of Energy.

- More power generation and longer service life: 30+ year service life and conversion efficiency of 98.8% Peak, 98.5% EU
- Lower OPEX: True Design for Service™ and cloud-connectivity for fewer and faster resolution of service events
- Higher system availability: fewer failures with predictive maintenance and faster time to repair with enhanced remote troubleshooting
- Deploy everywhere: designed and tested for any environment, NA and IEC codes and standards, and supported by worldwide field service network
- Secure: backed by a bankable company with 180 years of history and two decades of experience in solar inverters

Global specialist in energy management

160,000+ total workforce in 100+ countries 180 years of history

5% of Group revenues devoted to annual R&D spend

#### True Bankability with Schneider Electric

€27 billion in consolidated revenue

€2.1 billion adjusted net income

More than **7 GW** of Schneider Electric utility-scale inverters installed worldwide

## Reliable and cloud-connected

Conext SmartGen

#### Lifetime reliability

Through the most stringent selection and qualification of components, the Conext SmartGen™ is designed to have a 30-year lifespan with just one major preventive maintenance at mid-life in worst case conditions.

The most demanding reliability and environmental testing methodology, developed over 15 years experience in the PV industry, has been applied to ensure that the Conext SmartGen™ maintains adequate operating margins over its entire lifetime, in even the most severe environments.









 Built to last in the most severe environments (desert, tropical, continental, sea shore, high seismic)

 Greater uptime for increased power generation

Desert

Ocean

Continental

Tropical

#### True Design for Service™

Ease of service was the driving force behind big and small decisions that shaped the Conext SmartGen™.

From a comprehensive suite of diagnostics, troubleshooting and maintenance tools to quickly replaceable sub-assemblies, every step of servicing has been meticulously optimized to minimize operating expenses.






- · Designed for one hour mean time to repair and first time fix rate >97%
- · Advanced configuration and service tool with full local and remote functionality
- · Immediate access to all field replaceable systems and components

#### Predictive maintenance

Advanced predictive maintenance algorithms running in the Conext™ PowerCloud enable remaining lifetime estimation of major components, as well as failure prediction.



- Predict when components or systems may fail, ensuring they can be replaced just in time (not too early, and not too late)
- Reduce and defer maintenance costs by making decisions based on actual operating conditions

#### Local and remote interface - the Conext Viewer™

The most advanced inverter interface yet, providing local Wi-Fi and Ethernet connectivity as well as remote data access to inverter operational data.

Advanced troubleshooting, lifetime service logging, remote firmware upgrades, online service documentation and help files—all the power and capabilities of the digital world supporting your Conext SmartGen inverter.

- · Reduced learning curve that increases user satisfaction and minimizes risks
- Incorporated help mechanism that enables service personnel to do fast and accurate troubleshooting



## Product options

Conext SmartGen

#### IEC and NA versions

- NA version includes NEC compliant DC disconnect switches
- → Reduced footprint
- → Easier fuse servicing

#### Multiple grounding options

- · Floating with permanent insulation monitoring
- Negative or positive grounding with pre-connection insulation check, and RCD
- · Optional AC insulation monitoring
- → Enhanced personnel and equipment safety





#### Class I surge arrestors

- Selectable on DC mains, AC mains and AC auxiliary inputs
- → Enhanced protection against lightning strikes

#### Integrated communications and control panel

- · Modbus / TCP or Ethernet / IP gateway
- Optional communications hub for all skid mounted and field equipment
- Conext™Advisor 2 Programmable Logic Controller for fast controls of PV and ES inverters
- Copper or fiber optic switch options available for the communications hub
- → Allows for integrated monitoring and control hardware

#### Auxiliary power distribution panel

- Selection of auxiliary AC voltage (100/110/120/200/220/230/240V)
- Input circuit breaker with under voltage release
- · Auxiliary consumption metering
- · Power supply to string combiners
- → Elimination of external low voltage panel

### Varied DC input configurations

- 10 to 14 inputs with 160 to 400A fusing
- Input channel current monitoring
- → Wide range of overpaneling ratio

## Product specifications

Conext SmartGen

Device short name	CS2400 (Preliminary)				
Electrical specifications					
AC					
Nominal output power at at 40°C / 50°C	2200 kW (2400 kVA) / 2060 kW (2180 kVA)				
Nominal output voltage	600 V				
Nominal frequency	50/60 Hz				
Max. output current	2309 A				
Continuous operation output voltage range	+15% / -20% (480 - 690 V)				
Continuous operation frequency range	50 / 60 Hz +/- 10%				
Power factor	0 to 1 lead/lag				
Harmonic distortion (THDI)	< 3% at rated power				
Peak efficiency <sup>2</sup>	98.8%				
Weighted efficiency (EU weightings) <sup>2</sup>	98.5%				
Weighted efficiency (CEC) <sup>3</sup>	98.5%				
DC					
Max. input voltage range, MPPT	905 V - 1500 V				
Max. input voltage, open circuit	1500 V				
Max. input operating current	2481 A				
DC breaker short-circuit current (rated)	6000 A				
Max. rated short circuit current	Limited by DC inputs and fuse ratings. With max. 14 DC inputs x 400 A fuse rating: 4480 A STC, 5600 A absolute max (IEC) / 3584 A STC, 4480 A absolute max (NA).				
DC combiner	Integrated				
Number of DC inputs	10 to 14				
DC fuse rating	160A to 400A				
General specifications					
Service life	30 years <sup>6</sup>				
Power consumption, night time	< 295 W <sup>6</sup>				
Degree of protection	Outdoor (Type 4X / IP65)				
Enclosure	Aluminium				
Seismic rating	IEEE 693-2005 qualification to high seismic performance levels (ZPA = 1.0g 2% damping) IBC ICC-ES AC156-2012 certification to a SDS equal to 1.78g and with a z/h equal to 0 and IP=1.5 UBC Zone 4				
Product weight (approx.)	2800 kg (6160 lb)				
Product dimensions (H x W x D)	220 x 300 x 130 cm (86.6 x 118.1 x 51.2 in)				
Ambient air temperature for operation	-30°C to 60°C (-22°F to 140°F)				
Operating altitude	2,000 m without derating, up to 4,000 m with derating				
Relative humidity	5% to 100% condensing				
Features					
Type of cooling	Temperature-dependent low pressure closed-loop liquid cooling				
Graphic user interface	Conext <sup>™</sup> Viewer application for tablet and PC				
External communication interface	RS485/Modbus standard, Modbus over TCP/IP, and Ethernet/IP™ optional				
AC/DC disconnect	Integrated load-break-rated DC and AC circuit breaker standard				
Ground fault detection/interruption	PV insulation monitoring and RCD (on grounded PV configurations)				
Options					
	Grounding (floating, positive grounding, negative grounding), string current monitoring, class I surge arresters, AC insulation monitoring				
Standards (pending)					
Safety standards	IEC62109-1, and -2				
EMC standards	IEC/EN 61000-6-2 and -6-4, EN 55011:2016, CISPR 11 Ed. 6, FCC Class A				
Grid interconnection	IEEE1547 and 1547a, IEC61727				

<sup>&#</sup>x27;Up to 35°C Reactive power capability of 2200kVA leading and 2400kVA lagging.

Contact Schneider Electric for derating information.

\*Auxiliary self consumption not included, measured at minimum Vdc, Auxiliary self


sconsumption included.

<sup>4</sup>MPPT for power factor 1. Contact Schneider Electric for derating information.

Designed for a service life of 30 years with preventative maintenance. \$295 W maximum is with all communication hub options.

Heat exchanger is IP20 with IP65 components.







#### Appendix A: Technology Description

#### Hardware Topology

The Powin Energy base architecture is both flexible and robust, allowing deployments optimized for specific project performance requirements at minimal project cost. The base architecture can accommodate any cylindrical or prismatic cell chemistry, and cell-level battery management software (BMS) and auxiliary cell conditioning ensure that each individual cell will perform at its full potential while collecting sub-second data on each along the way.

The battery energy storage system (BESS) is an integrated system of battery arrays, power conversion systems (PCS), transformers, and energy management controls. At the core of the BESS is the battery module, a collection of cylindrical or prismatic cells housing the chemistry where charge and discharge originate from. The proposed BESS employs lithium iron phosphate chemistry in the battery cells, the safest lithium ion chemistry on the market. Lithium iron phosphate batteries offer the most balanced optimization between cost, energy density, cycle life, safety and stability making it an optimal choice for stationary energy storage solutions. Each cell has a cycle-life of 4500 cycles, provided the BESS is operated within product specifications.

The module boasts industry leading cell management through its auxiliary power supply, parallel wiring to each cell, and cell-level management and diagnostic software. These design features combine to provide sub-second recording of cell voltage, temperature and state of charge (SOC) and ensure that each cell remains within 10 mV of optimal state at all times.

The modules are arranged in racks totaling 140 kWh to create the Stack140, the workhorse of the Powin Energy fleet (Figure A.1). Stack140s are wired in parallel in arrays to achieve the desired project energy capacity. Each array is managed by the Powin Energy Array Cabinet, which has a maximum capacity of fifteen Stack140s per array cabinet totaling approximately 2 MWh of maximum capacity per array (Figure A.2). Arrays can be multiplied as needed to achieve the overall desired site energy capacity for sites requiring greater than 2 MWh of capacity (Figure A.3).

www.powinenergy.com [1]








Figure A.1 – Powin Energy next generation Stack140 modular DC battery system.




Figure A.2 – Powin Energy 2.5 MWh outdoor product with a portion of the array visible

ww.powinenergy.com [2]






Figure A.3 - Powin Energy first generation indoor battery energy storage system project operating in Irvine, California.

The system presents an average round-trip efficiency of 92%, though exact efficiencies will depend upon ambient temperatures, charge and discharge rates, and other local factors. Though the BESS operates and collects system data autonomously, it is remotely monitored by Powin Energy at all times.

#### **Battery Management System**

Powin Energy's next generation hardware was designed in part to allow deployment of its advanced software at every level of the BESS. In doing so, this battery management system ensures safety, reliability, efficiency and scalability at each level. The basic software architecture of the BMS provides distributed intelligence, controls and data management at the System, Array, Stack, Module and Cell Levels.

Powin Energy's Energy Management Software (EMS) is the architecture's portal to the grid or off-taker and deploys instructional and statistical algorithms to and from the BESS based on the signals it receives from outside word; in that way it is the brain for any given site. From here the EMS coordinates with cloud-based Powin Fleet Management tools at the Powin Command Center, where a secure server provides remote monitoring and control capabilities, though every Powin site can perform autonomously.

The robustness and scalability afforded by the system software ensures that the scalability of the hardware design will be fully realized from small, behind the meter applications to large, in front of the meter applications. Site communications are performed through MODBUS via a hardline connection with 4G wireless backup.

www.powinenergy.com [3]



#### System Control Layer

The system control layer is the interface with the EMS. The bi-directional interface is used to transmit aggregated data to the cloud where query and response communications are managed. System control scripts deploy commands and, when necessary alarms, both from the cloud and natively if cloud connectivity is compromised.

The system control layer at the top of the hierarchy has primary functionality for monitoring and managing the battery arrays, strings, packs and modules individually and as a system. This layer also communicates with the EMS, and provides automatic system protection, including environmental monitoring with fire detection and suppression. The system controller electronics are housed in a standard 19" rackmountable enclosure.




Figure A.5: Screenshot of our cell level voltage monitoring data user interface




Figure A.6: Screenshot of our cell level temperature monitoring data user interface

www.powinenergy.com [4]






Figure A.7: Screenshot of the dashboard of the control and monitoring interface for our EMS (System Controller)

www.powinenergy.com [5]



#### Array Control Layer

The array control layer monitors DC voltage and current, and determines the amp-hour capacity of the battery strings needed to increase the DC voltage to the level required by the power conversion system (PCS). The battery string controller electronics are housed in a standard 19" rack enclosure, which can also house the system controller in smaller configurations.

#### Module Control Layer

The battery pack control layer passively and actively balances voltage, temperature, state of charge (SOC) across all battery cells. This layer also monitors and records charge and discharge history of individual packs, as well as the balance state across all cells and packs.

This layer is also responsible for charge protection, which detects and alerts conditions such as:

- over and under voltage,
- high and low temperature,
- excessive temperature change,
- fire risk,
- over charge and discharge,
- and weak cell conditions.

Advanced algorithms are used to detect weak or defective battery cells, and this information is then used by Powin Energy's Warranty Tracker™ to submit a warranty claim and triggers a mitigation action onsite.

Powin Energy's patented architecture is designed to achieve true battery cell agnosticism. While other DC system providers in the market falsely claim similar functionality, Powin can integrate a new battery cell technology into its base architecture without disrupting the critical path of most projects. This empowers Powin to give its customer more of what they want whether it is a lower price, higher energy density or any other performance metric derived from any cylindrical or prismatic battery cell. This proposal features lithium iron phosphate chemistry, configured into 8.2 kWh battery packs, which provides industry leading safety, high energy density, rapid charging and discharging capacity, and other characteristics needed in demanding applications.

#### Cell Control Layer

At the bottom of the hierarchy is the cell control layer, which monitors and records the voltage and temperature of the individual cells connected in parallel within each module, and provides this information to the module control layer. Every battery module consists of a group of battery cells connected in parallel, and each module has its own, dedicated controller that is also responsible for implementing cell balancing commands, as well as taking any actions necessary to protect the cells.

#### **Passive and Active Balancing**

Powin Energy battery modules provide both passive and active balancing. Passive balancing can be programmed to maintain the voltages of individual battery pack cells to within a specified range of each other during battery charging and discharging. Passive balancing can also be used to maintain the states

vww.powinenergy.com [6]



of charge of all battery pack cells to within a specified percentage of each other. Active balancing is used primarily to maintain voltage and state of charge balances across different battery packs, and optionally for the cells in each pack when operated in conjunction with passive balancing. A combination of active and passive balancing normally provides the most cost-effective for scaling battery storage.

#### **Battery Pack Warranty Tracker**

The Powin Energy Warranty Tracker™ is an innovative and valuable capability of the battery pack control layer. The Warranty Tracker monitors the status and records the history of all battery pack activities, including the module voltages and temperatures, charging and discharging, and the balance state of the battery pack modules. The Warranty Tracker then reports any conditions that infringe on the warranty, and this information is used to help troubleshoot problems in the battery cells or the operation of the battery cells.

Below is a general specification for a standard Powin Energy BESS unit. Component and system ratings may vary due to project requirements.

www.powinenergy.com [7]



## Powin Energy – Stack Product Data & Specification for Battery Energy Storage System (DC Only)

#### **BESS Product Data**

Nominal Energy Storage Capacity (MWh)

Output Voltage (VAC)

Operating Temperature (°C)

Roundtrip Efficiency

**Battery Technology** 

Calendar Life (yr)

Dimensions per array

See Stack Data Sheet

LV/MV based on transformer

10°C to 35°C

DC - 94%

AC (inc. inverter) – 91%

LFP Li-ion power cells

20 Years

40' L x 8'W x 8'6" H

#### **Advanced Features**

First class battery pack warranty

Battery management system with built in warranty tracker and battery odometer

Adaptable energy management system

Locally programmable & remotely controlled

through RS485

Single Point of Connection for Power and

Communication wiring

#### General Specification & Technical Data

#### **Battery-Based Storage Technology**

**Battery Technology** 

Battery Chemistry

Cycles at 80% DOD (cycles)

LFP

3650 @ C/4

Lithium iron phosphate

www.powinenergy.com [8]



#### **Battery Pack**

Weight (lbs) 82 lbs (approximate)

Nominal Energy (kWh) See Stack165 Data Sheet

Nominal Pack Capacity (Ah) See Stack165 Data Sheet

Nominal Voltage (VDC) 51.2VDC

Cell Cycle Life Maximum 4500 cycles >80% of original capacity

(1C/4C, 25°C, 100% DOD)

Storage Temperature -20°C ~ 45°C for 3 months, -20°C ~ 35°C for 12 months

Operating Temperature 5°C ~ 45°C, charge, 0°C ~ 45°C, discharge

Dimensions (L x W x H) 20.71"L x 18.09"W x 7.01"H (4U rack mount)

#### Battery Management System (BMS)

Cell Level Module control protects cells

Pack Level Pack control balances cell pack
Array Level String control equalizes current

Main control layer manages charging and

System Level discharging

#### **Powin Controls System**

Standard Features

Web based user interface

Server and communications package

Designed for multiple use-cases throughout a single day responding to ISO dispatch signals including peak demand reduction, load-shifting, solar firming, solar smoothing, demand response, frequency regulation, voltage control, energy arbitrage and more.

www.powinenergy.com [9]



#### Appendix B: Brief Company Profile

Founded in 1990 Powin Corporation has been a consistent leader in the manufacturing and commercial goods sector. With annual revenues exceeding \$60 million they supplied quality products to such familiar US brands as Daimler Benz, Camp Chef and NordicTrak. That success allowed Powin to enter the energy space, and in 2011 Powin Energy was formed to research, develop and patent the unique battery management and operating system that currently forms the basis of our bp-OS. With this development and testing work completed by mid-2016, Powin Corporation shed its heritage businesses to become the pure-play, energy storage product company Powin Energy is today.

From our headquarters in Greater Portland, Oregon and factory in Yangzhao, China, Powin is delivering the next generation of safe and scalable battery energy storage systems (BESS) purpose-built for the demands of utility-scale applications. Leveraging our bp-OS battery management system, vertically-integrated manufacturing capabilities, decades of procurement expertise in Asia, and deep experience in the US energy domain, we are delivering today the lowest cost and most reliable BESS available on the market. Powin's BESS is also the only battery storage system on the market today that gives its customers multi-layer dynamic control and rich visibility into the health of their energy storage system down to the cell level, empowering more efficient system operation and simpler maintenance and warranty claim resolution.

As evidence of the capabilities and competitiveness of our offering, since entering commercialization in late 2016, Powin has built a pipeline of over 100 MWh of contracted energy projects. Our first utility-scale project was delivered on-time to support local capacity concerns stemming from Southern California's Aliso Canyon disaster. We are following this up by delivering Canada's largest energy storage project in Stratford Ontario which will be operational by March, 2018.

Our team's diverse background gives us unique understanding of the financial, operational, and cost challenges presented by utility-scale energy projects. We see it as our job to reduce the procurement, execution, and integration challenge of energy storage projects which we believe will result in on-time, under budget projects with superior ROI.

Powin Energy is a registered Minority Business Enterprise (MBE/DBE) and publicly listed as PWON on OTC-QB exchange.

ww.powinenergy.com [10]



Appendix D: Project Experience

Project: Powin Stratford 8.8 MW/40.8 MWh

COD: March 2018

Powin Energy products and services were selected by Hecate Energy to build, deliver, and install six projects at two sites totaling 12.8 MW/52.8 MWh in Ontario, Canada. The projects were all contracted with Independent Electricity System Operator (IESO) as part of their long-term energy plan. Though not all six were taken forward, those that remained total to 40.8 MWh and comprise the largest contract for energy storage in Canada. The project is located in Stratford, Ontario and will be housed inside of a newly constructed building specifically designed to support twenty Powin Energy 2 MWh battery arrays. The project is contracted to provide reactive service voltage control for the IESO.

Project: SCE Aliso Canyon Millikan 2 MW/9 MWh

COD: December 2016

Powin Energy's 2 MW/9 MWh project was selected through a competitive solicitation initiated in response to the California Public Utilities Commission's (CPUC) Aliso Canyon Energy Storage (ACES) request for energy storage systems that could be operational by the beginning of 2017. The Powin Energy BESS is interconnected on the Virgo 12 kV distribution line out of the Estrella 66/12 kV substation and can deliver 2 MW of power for over four continuous hours, providing a reliable and continuous source of energy during peak demand events. In addition, the system will supply frequency regulation and flexible capacity support as needed.

Project: BPA Technology Innovation Project # 260

This project deployed a 120 kW/500 kWh energy storage unit and multiple computer simulated storage units, which together make up a utility scale battery energy storage system. The project sought to establish costs and benefits, verify technical performance, and validate the reliability and durability of a scalable, modular, dispatchable battery storage system and to determine and evaluate how best to deploy and control the battery storage system to meet a number of demand response applications as well as the operational challenges facing BPA with regards to operational reserve and capacity constraints caused by increased wind integration, Federal Columbia River Power System management, and transmission expansion challenges.

Project: Energy Northwest Demand Response Aggregated Controls Systems (ENDRACS)

Powin Energy and Energy Northwest executed an Aggregated Demand Response Pilot Project Aggregated-Asset Agreement where Powin Energy was considered a "Utility". The scope of the pilot project (Pilot) tested demand response integration and management of resources between the Utility's Asset (BESS unit) and Energy Northwest/BPA. The Pilot allowed Energy Northwest and BPA to use the experience gained and data collected to help determine the applicability of utilizing load flexibility to manage a variety of transmission and utility-scale conditions via aggregated demand response. For each event Energy Northwest notified Powin Energy with an event request notice and an event termination notice.

www.powinenergy.com [11]



#### Appendix E: References

Gabe Wapner
Director – Development
Hecate Energy
621 W. Randolph Street
Chicago, IL 60661
+1.518.788.7337
GWapner@HecateEnergy.com

Maria Litos
Energy Contracts
Southern California Edison
2244 Walnut Grove Avenue. Rosemead,CA 91770
+1.626.302.3233
maria.litos@sce.com

Thor Hinckley (now with CLEAResult)
Bonneville Power Administration
100 SW Main Street, # 1500
Portland, OR 97204
+1.503.706.3977
thor.hinckley7@clearesult.com

John Steigers
Energy Northwest
PO Box 968
Richland, WA 99352-0968
+1.509.377.4547
jasteigers@energy-northwest.com

powinenergy.com [12]



## **Proof of Site Control/Executed Lease**

## Land Lease Option and Lease Agreement (Solar Farm)

#### **BETWEEN:**

Derek D. Butler & Sheena M. Butler, LANDLORD

**AND** 

GREENSKIES RENEWABLE ENERGY LLC, TENANT

# LAND LEASE OPTION AND LEASE AGREEMENT (SOLAR FARM)

This Land Lease Option and Lease Agreement (the "Agreement") is made this \_\_\_\_\_\_\_, 2018, by and between Derek D. Butler & Sheena M Butler, each a Landowner, having an address of 4 Bel-nel Road, Royalston, MA 01368-9497 ("Landlord"), and Greenskies Renewable Energy LLC(or assigns), a CT Limited Liability Company, having an office at 180 Johnson St., Middletown, CT 06457 ("Tenant").

#### 1. The Option.

- a. For the sum of "Option Fee") to be paid to Landlord by Tenant upon execution of this Agreement and in consideration of the mutual promises contained herein and other good and valuable consideration, the receipt and sufficiency thereof is hereby acknowledged, Landlord hereby grants to Tenant the exclusive and irrevocable right and option to lease the Leased Premises (as defined below) on the terms and conditions set forth below (the "Option").
- b. The term of the Option shall commence on the date hereof and shall continue in full force and effect for eighteen (18) months from the date of this agreement (the "Initial Option Period").
- c. Extension Option Periods. The option period may be extended by Tenant for two (2) six (6) month periods (the "Extension Option Period(s)") upon Tenant's written notice to Landlord before the end of the Initial Option Period or prior Extension Option Period, as applicable, together with payment of the Initial Option Period and Extension Option Periods are hereinafter collectively referred to as the "Option Period").
- d. During the Option Period, Landlord shall permit Tenant and its authorized agents and representatives to enter upon the Landlord Property (as defined below) at reasonable times during normal business hours to inspect the Landlord Property and perform surveys. Tenant shall notify Landlord of its intention, or the intention of its agents or representatives, to enter the Landlord Property at least twenty-four (24) hours prior to such intended entry. Tenant shall bear the cost of all inspections
- e. Exercise of the Option. No later than 5:00 p.m. on the last day of the Option Period, Tenant shall have the right, in its sole and absolute discretion, to exercise the Option by giving Landlord written notice of such exercise in accordance with the Notice provision set forth in Section 15 (the "Option Notice").
- f. Upon Tenant's exercise of the Option, the terms of this Agreement relating to the lease of the Leased Premises (the "Lease") that follows

- shall take effect. The date that the Option Notice is delivered shall be considered the "Lease Commencement Date".
- g. In the event Landlord fails to perform its obligations under this Agreement for any reason other than Tenant's breach, Tenant may pursue all remedies available at law and in equity. Landlord hereby acknowledges that Tenant will incur significant expenses in reliance on this Agreement.
- 2. <u>Leased Premises</u>. Upon Tenant's exercise of the Option, Landlord shall lease to Tenant and Tenant shall lease from Landlord pursuant to the terms of this Agreement, an approximately 7 acre parcel of real property, which is a portion of the real property located at 4 Bel-Nel Road, Royalston, MA, which property is more particularly described in <u>Exhibit A-1</u> attached hereto ("Landlord Property"), together with ingress, egress, and utility easements approximately as shown on Exhibit A-1 providing access to and from a public road and the point of utility interconnection, as described in Sections 5 and 6 below (that portion of the Landlord Property being referred to herein as the "Leased Premises"). A legal description of the Leased Premises is attached hereto and incorporated herein as <u>Exhibit A-2</u>.
  - 3. <u>Term</u> The lease term (collectively, the "Term") shall be as follows:
    - a. The initial Term of the Lease shall comment on the Lease Commencement Date and continue until the date that is 21 years following the commercial operation date of the solar facility to be located on the Leased Premises (the "COD"), such period of time being referred to as the "Primary Term", provided however, such COD shall not be later than 48 months following the Lease Commitment Date.
    - b. Tenant shall have the option and right to elect to extend this lease for up to Two (2) five (5) year extensions (each such extension referred to as a "Renewal Term", or collectively as the "Renewal Terms"). Tenant shall give Landlord written notice of its election to extend the Lease on or before the commencement of the final year of the Primary Term, or the end of the then-current Renewal Term, whichever is later.
    - c. A final term commencing upon expiration of the Primary Term, or expiration of the last Renewal Term, whichever is later, to allow for Tenant's decommissioning and removal of the Solar Farm (as defined below) (the "Final Term"). The Final Term shall last no longer the six (6) months, unless extended per mutual written agreement of Tenant and Landlord.
- 4. Rent. In consideration for Landlord leasing the Leased Premises to Tenant, Tenant agrees to pay during the Term to Landlord in lawful money of the United States of America, basic rent as follows (collectively, the "Basic Rent"):
  - a. <u>Primary Term Rent</u>. Commencing on the Lease Commencement Date and continuing on each anniversary thereafter (the "Payment Due Date"), with

IN WITNESS WHEREOF, the parties hereto have executed this Agreement, as a sealed instrument, as of the day and year first above written.

LANDLORD:	TENANT:
Derek D. Butler & Sheena M. Butler	Greenskies Renewable Energy LLC (or Assigns)
By: Do	By:
By: Jun Butte	Title: LEO
Date: 8/2/18	Date: 8/3/18
restant to the second s	
COMMONWEALTH OF Massachesetts	)
COUNTY OF Worcester	) ss )
proved to me on the basis of satisfacto	Notary Public No
COMMONWEALTH / STATE OF Connect	ticut)
COUNTY OF Middlesex	) ss )
On this 30d day of August, 2 in and for said Commonwealth/State, personally on the basis of satisfactory evidence of identifications.	2018, before me, the undersigned notary public appeared Steinley Chin proved to me ation, which were <u>personally Known</u> , to beding or attached document, and acknowledged starily for its stated purpose (as Landlord).
WITNESS my hand and official seal.	6106
	Notary Public SARAH C. SMITH
	Notary Public  SARAH C. SMITH  NOTARY PUBLIC  State of Connecticut  My Commission Expires  My Commission Expires
2	

EXHIBIT A-1
LEGAL DESCRIPTION OF THE LANDLORD PROPERTY




#### **EXHIBIT A-2**

#### LEGAL DESCRIPTION OF THE LEASED PREMISES

Green line: leasable area

All access easements and/or transmission easements shall take place on the abutting property to the north.



# Land Lease Option and Lease Agreement (Solar Farm)

**BETWEEN:** 

Anthony J. Basso, LANDLORD

**AND** 

GREENSKIES RENEWABLE ENERGY LLC, TENANT

# LAND LEASE OPTION AND LEASE AGREEMENT (SOLAR FARM)

This	Land	Lease	Option	and	Lease	Agreement	(the	"Agreement")	is	made
this			, 2	<b>018,</b> b	y and be	tween Anthor	y J. B	asso, a Landov	vner,	having
an ado	iress of	4 King S	Street, Ro	yalsto	n MA ("	'Landlord"), ai	nd Gre	enskies Renew	able !	Energy
LLC(	or assig	ns), a C	T Limite	d Lia	bility C	ompany, havi	ng an	office at 180 J	lohns	on St.
Midd	letown.	CT 0645	57 ("Tenar	nt").	•		•			•

#### 1. The Option.

- a. For the sum of "Option Fee") to be paid to Landlord by Tenant upon execution of this Agreement and in consideration of the mutual promises contained herein and other good and valuable consideration, the receipt and sufficiency thereof is hereby acknowledged, Landlord hereby grants to Tenant the exclusive and irrevocable right and option to lease the Leased Premises (as defined below) on the terms and conditions set forth below (the "Option").
- b. The term of the Option shall commence on the date hereof and shall continue in full force and effect for eighteen (18) months from the date of this agreement (the "Initial Option Period").
- c. Extension Option Periods. The option period may be extended by Tenant for two (2) six (6) month periods (the "Extension Option Period(s)") upon Tenant's written notice to Landlord before the end of the Initial Option Period or prior Extension Option Period as applicable, together with payment of the Initial Option Period and Extension Option Periods are hereinafter collectively referred to as the "Option Period").
- d. During the Option Period, Landlord shall permit Tenant and its authorized agents and representatives to enter upon the Landlord Property (as defined below) at reasonable times during normal business hours to inspect the Landlord Property and perform surveys. Tenant shall notify Landlord of its intention, or the intention of its agents or representatives, to enter the Landlord Property at least twenty-four (24) hours prior to such intended entry. Tenant shall bear the cost of all inspections
- e. Exercise of the Option. No later than 5:00 p.m. on the last day of the Option Period, Tenant shall have the right, in its sole and absolute discretion, to exercise the Option by giving Landlord written notice of such exercise in accordance with the Notice provision set forth in Section 15 (the "Option Notice").
- f. Upon Tenant's exercise of the Option, the terms of this Agreement relating to the lease of the Leased Premises (the "Lease") that follows

- shall take effect. The date that the Option Notice is delivered shall be considered the "Lease Commencement Date".
- g. In the event Landlord fails to perform its obligations under this Agreement for any reason other than Tenant's breach, Tenant may pursue all remedies available at law and in equity. Landlord hereby acknowledges that Tenant will incur significant expenses in reliance on this Agreement.
- 2. <u>Leased Premises</u>. Upon Tenant's exercise of the Option, Landlord shall lease to Tenant and Tenant shall lease from Landlord pursuant to the terms of this Agreement, an approximately 8.3 acre parcel of real property, which is a portion of the real property located at 4 King St, Royalston, MA, which property is more particularly described in <u>Exhibit A-1</u> attached hereto ("Landlord Property"), together with ingress, egress, and utility easements approximately as shown on Exhibit A-1 providing access to and from a public road and the point of utility interconnection, as described in Sections 5 and 6 below (that portion of the Landlord Property being referred to herein as the "Leased Premises"). A legal description of the Leased Premises is attached hereto and incorporated herein as <u>Exhibit A-2</u>.
  - 3. Term The lease term (collectively, the "Term") shall be as follows:
    - a. The initial Term of the Lease shall comment on the Lease Commencement Date and continue until the date that is 21 years following the commercial operation date of the solar facility to be located on the Leased Premises (the "COD"), such period of time being referred to as the "Primary Term", provided however, such COD shall not be later than 48 months following the Lease Commitment Date.
    - b. Tenant shall have the option and right to elect to extend this lease for up to Two (2) five (5) year extensions (each such extension referred to as a "Renewal Term", or collectively as the "Renewal Terms"). Tenant shall give Landlord written notice of its election to extend the Lease on or before the commencement of the final year of the Primary Term, or the end of the then-current Renewal Term, whichever is later.
    - c. A final term commencing upon expiration of the Primary Term, or expiration of the last Renewal Term, whichever is later, to allow for Tenant's decommissioning and removal of the Solar Farm (as defined below) (the "Final Term"). The Final Term shall last no longer the six (6) months, unless extended per mutual written agreement of Tenant and Landlord.
- 4. Rent. In consideration for Landlord leasing the Leased Premises to Tenant, Tenant agrees to pay during the Term to Landlord in lawful money of the United States of America, basic rent as follows (collectively, the "Basic Rent"):
  - a. <u>Primary Term Rent</u>. Commencing on the Lease Commencement Date and continuing on each anniversary thereafter (the "Payment Due Date"), with

IN WITNESS WHEREOF, the parties hereto have executed this Agreement, as a sealed instrument, as of the day and year first above written.

LANDLORD:	TENANT:
Anthony J Basso	Greenskies Renewable Energy LLC (or Assigns)
By: Cheffen	By: Stanley Cl
Title:	Title: (EO
Date: 08-02-18	Date: 4/3/18
ing the state of t	
COMMONWEALTH / STATE OF Massacle COUNTY OF Worksfer	usetts_)
COUNTY OF Workester	) ss )
in and for said Commonwealth/State, personally on the basis of satisfactory evidence of identification be the person whose name is signed on the precedence of the person whose name is signed on the precedence of identification with the person whose name is signed on the precedence of identification with the person whose name is signed on the precedence of identification.  WITNESS my hand and official seal.	Notary Public No
Commonwealth / State of Middles	
COUNTY OF Middlesex	)
on the basis of satisfactory evidence of identification	appeared Stanky Chin proved to me ation, which were personally known, to ceding or attached document, and acknowledged starily for its stated purpose (as Landlord).
WITNESS my hand and official seal.	
2	Notary Public  SARAH C. SMITH  NOTARY PUBLIC  State of Connecticut  My Commission Expires  July 31, 2020

EXHIBIT A-1
LEGAL DESCRIPTION OF THE LANDLORD PROPERTY




EXHIBIT A-2
LEGAL DESCRIPTION OF THE LEASED PREMISES

Green line: leasable area





**Zoning Map** 





### Operations and Maintenance Plan Emergency Response Plan





#### **O&M AGREEMENTS**

There are several ways to create a service agreement with us. One is time and materials, another is an on-going service agreement and last is a custom package that is designed to fit your service needs. Whether packaged or a la carte, we can help find a solution to protect your solar installation now and for the life of the system.



TARGET CYPRESS, CA 221.34 kW


O&M SERVICE AGREEMENT OPTIONS & OFFERINGS	As Needed	Service Agreement
MONITORING		Part and a
24/7 assessment of systems in real-time		×
Integrated with existing systems	er elle er a	x
Work with systems no longer actively monitored		×
Custom alarm management		x
Customer monitoring & analytics identify smallest variances in production		×
Weekly system performance analytics		×
REPORTING		
Real-time		X
Monthly		×
Quarterly	and the second s	×
Yearly		× × ×
Annual bulk download from 3rd party non-integrated system	×	The state of the same
FIELD OPERATIONS		
Certified electrician and solar technicians	×	×
Scheduled Maintenance		×
Emergency Maintenance	×	×
Warranty Services	×	×



# PROACTIVE MAINTENANCE STRATEGY

#### SCHEDULED MAINTENANCE PLAN

- Greenskies utilizes a semi-annual scheduled maintenance plan to identify and correct any issues. Reports are generated after each visit and performance data is analyzed and saved so that historical data can be used to track module performance vs. warrantied output.
- Spring Visits allow teams to visually inspect the array and its components after they have been put through the physical rigors of the winter season and allow any issues to be corrected before the system enters into its most productive season.
- Fall Visits allow teams to inspect the array and components after they have been through the most electrically demanding season and correct any issues that may have resulted during peak performance over this extended period.



**SOLAR TECHNICIAN INSPECTING ELECTRICAL WIRING** 

#### **EMERGENCY MAINTENANCE VISITS**

- When a system is not producing or is under producing the Data Acquisition System will create an alarm. Once an alarm is created the production analyst will analyze the data. Subsequently, O&M trucks are dispatched to investigate and correct any issues.
- Greenskies O&M has a close working relationship with our major system component manufacturers, including modules, racking and electrical components/enclosures.
- We perform warranty work with our in house technicians. We have centrally located warehouses which store spare modules, inverters, wire and other components that can be used for on-site replacements.
- Deck Monitoring provides Greenskies with real-time production data and alarms to help manage system uptime. Automated dispatch to projects dependent on generation loss and location make our solar techs more efficient in correcting site issues.
- Greenskies O&M teams utilize cutting edge technology to test and inspect all major system components and connections on its arrays.




# MAINTAINING YOUR SOLAR SYSTEM

We provide Operations and Maintenance (O&M) services for the duration of the service contract. We're able to monitor every system remotely, track production, and, through a team of field technicians, respond to alerts so your system stays up and running.

#### MONITORING

- Greenskies O&M currently monitors and maintains all of our operational assets in-house, along with third party clients.
- A team, including the system analysts and field operations coordinator, monitor our systems 24 hours a day, 7 days a week.
- The operations center utilizes Also Energy's platform for site monitoring and generation reporting, along with a custom built in-house platform designed specifically for improved site analytics and site issue prioritization.



- Custom alarm management provides instantaneous notifications to our Network Operating Center.
- Alarms verified by our analysts are put into the site issues docket. Custom algorithms determine each issue's prioritization score based on type of issue, kW impacted and duration of time.



**OPERATIONS CENTER MIDDLETOWN, CT** 

- Custom monitoring and analytics identify the smallest production issues that usually go undetected, to maximize energy output.
- System performance analytics are completed weekly to better understand the health of each asset, and find trends in under producing systems.

#### FIELD OPERATIONS

- Each O&M field team consists of a certified electrician and a solar technician.
- Greenskies field crews perform two Preventative Maintenances visits per system each year.
- Regionally structured crews allow for a quicker response time to corrective maintenance tasks.
- O&M technicians are efficient in identifying and correcting any site issues that may arise.
- Working relationships with manufacturers provide faster for normal warranty work services.
- Greenskies field crews utilize the most advanced technology for PV testing and diagnostics of site issues.



# OPERATIONS & MAINTENANCE (O&M) OVERVIEW

#### SERVICING OVER 170 MW AT 320+ SITES ACROSS THE UNITED STATES

Greenskies, a Clean Focus company, develops, constructs, operates, and maintains renewable-energy projects throughout the United States. We deliver high-quality solar projects to provide our clients with clean, reliable electricity.

#### WORRY FREE MAINTENANCE



#### MAXIMIZE YOUR SOLAR INVESTMENT

To ensure maximum energy output over the life of your solar installation with custom service agreements:

- · Guaranteed higher production
- Get more value from your system

#### Greenskies O&M Services include:

- · Competitive pricing
- · Regional teams of field technicians
- · Guaranteed 24-hour response time for emergency maintenance requests
- Established relationships with manufacturing/production companies help ensure timely turnaround on warranty work
- Custom monitoring platform maximizes system output finding lapses in production that other systems miss



#### Visual-Mechanical Checklist for Annual Preventative Maintenance & Emergency Response Plan

#### 1. Monitoring System Data Review

- 1.1. Review and/or modify fault and performance alarms, thresholds, and notifications.
- 1.2. Review activated alarms and provide feedback as necessary for further action.

Completed 1x per year

#### 2. General Site Inspection

- 2.1. Verify safety and Identification labeling is present and legible.
- 2.2. Inspect site access/egress locations are free of obstructions and hazards.
- 2.3. Security means and installation methods (Surveillance equipment inspection not included).
- 2.4. Equipment access lanes are free of obstructions and hazards.
- 2.5. Inspect for changes of environmental conditions such as nearby construction activity, agricultural activities, bird migrations, water table changes, acts of vandalism, and shading.

Completed 1x per year

#### 3. Mechanical System Inspection - (Racking, Modules)

- 3.1. Racking structures visual and mechanical inspection.
- 3.2. Mechanical inspection 2% of Module-to-racking attachments for torque specification.
- 3.3. Module visual inspection.
- 3.4. Foundations, driven piers, mechanical attachments, and earth screw visual inspection.
- 3.5. Equipment Grounding Conductor electrical continuity inspection.
- 3.6. Equipment bonding to ground electrical continuity inspection.

Completed 1x per year

# 4. DC & AC Electrical System Inspection - (DC Collection Panels, AC Collection Panels, Safety Disconnect Switches)

4.1. Verify safety and Identification labeling is present and legible.



- 4.2. Enclosure mounting, gaskets, interior, and exterior visual inspection Equipment.
- 4.3. Grounding and bonding inspection.
- 4.4. Terminations (conductors) thermography scanning.
- 4.5. Visual inspection of conductor termination torque markings.
- 4.6. Fuse and breaker thermography scanning.
- 4.7. Visual inspection of conduits, fittings, junctions/splice boxes, and enclosures.

#### Completed 1x per year

#### 5. Inverter Inspection

- 5.1. Verify safety and Identification labeling is present and legible.
- 5.2. Enclosure mounting, gaskets, interior, and exterior visual inspection.
- 5.3. Grounding and bonding inspection.
- 5.4. Inverter operation verification.
- 5.5. Thermography scanning of terminations, fuses, breakers, and electronics.
- 5.6. Vacuum clean interior.
- 5.7. Per manufacturer's recommendations, clean air intake/exhaust screens, fans, and filters.
- 5.8. Supply and install new inverter filters per manufacturer's requirements.
- 5.9. Complete all other manufacturer specific maintenance procedures not listed above.

#### Completed 1x per year

#### 6. Data Acquisition System Inspection

- 6.1. Verify safety and Identification labeling is present and legible.
- 6.2. Battery health inspection (when applicable).
- 6.3. Meteorological data sensor cleaning, positioning, and operation.
- 6.4. Inverter communication (when applicable).

#### Completed 1x per year

#### 7. Reporting

- 7.1. Provide digital commissioning report including results from all steps with responses noting Pass, Values, or Failure with explanation.
- 7.2. Photo report of deficiencies.
- 7.3. NABCEP PV Installation professional to review reports for completeness.

Completed 1x per year



#### **Corrective Repairs**

Repairs found by the O&M provider during inspection visits deemed readily repairable will be promptly attended to in the following steps:

- O&M provider will request CRE permission to execute work
- Upon approval, O&M provider will complete repairs and send work order report to CRE within two business days

The following steps will be taken if GWU or CRE finds a system component that needs repaired while O&M provider is not on site:

- O&M provider will confirm receipt of CRE's request with written response
- · O&M provider will dispatch technician within guaranteed response time
- O&M provider will complete repairs and send work order report to owner within two business days

#### **Emergency Response Plan**

In case of an on-site emergency that calls for the immediate shutdown of the Solar System, please follow the below procedure. In the event of an emergency not caused by the Solar System, whereupon the client chooses to shut down the Solar System, the client shall be responsible for all lost generation during the time the System is inactive. The procedure for shutdown is as follows:

- 1. In the event of a fire or an emergency requiring emergency services, Call 911 immediately
- 2. Open AC Disconnects at the service location to de-energize AC power to the site.
- 3. Call Greenskies O&M

#### Contacting Greenskies O&M

- Tier 1 Communications
  - Contact the Greenskies Field Operations Office
    - Direct Phone Line 860-398-5408 ext 323
    - Email OM office@greenskies.com
- <u>Tier 2 Communications</u> If you do not get an immediate response from Tier 1 contacts please contact the following:
  - Contact Greenskies Escalation
    - Direct Phone Line 860-598-4890
- <u>Tier 3 Communications</u> If you do not get an immediate response from Tier 2 please contact the following:
  - Brandon Sheridan Manager of Field Operations
    - Personal Phone (203) 915-7722
    - Email bsheridan@greenskies.com



- o David Rutty Vice President of Operations and Maintenance
  - Personal Phone (203) 314-8382
  - Email drutty@greenskies.com



# **Proof of Liability Insurance**

Client#: 198815 GREEN105

#### ACORD...

#### **CERTIFICATE OF LIABILITY INSURANCE**

DATE (MM/DD/YYYY) 6/12/2018

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

IMPORTANT: If the certificate holder is an ADDITIONAL INSURED, the policy(les) must be endorsed. If SUBROGATION IS WAIVED, subject to the terms and conditions of the policy, certain policies may require an endorsement. A statement on this certificate does not confer rights to the certificate holder in lieu of such endorsement(s).

certificate holder in lieu of such endorse	ment(s)	·							
PRODUCER			CONTAC MAME:						
Couch Braunsdorf Insurance Grp			PHONE (AJC, No, Ext): 800 223-5433 FAX (AJC, No): 908-580-1274					80-1274	
PO BOX 888		Ĭ	E-MAIL ADDRES						
701 Martinsville Rd.					INSURER(S) AF	FORDING COVERAG	GE		NAIC #
Liberty Corner, NJ 07938-0888			INSURE	R A : AXIS Special	ty London				
INSURED			INSURE	R B : (CHA) - Conti	Inental Casualty Con	препу			20443
Greenskies Renewable Eng	rgy LL(	;	INSURE	C : (CHA) - Valle	y Forge Insurance C	Company	-		20508
PO Box 251			INSURE	RD:					
Middletown, CT 06457			INSURE						
			INSURE						
COVERAGES CERT	IFICATE	NUMBER:				REVISION NUM	BER:		
THIS IS TO CERTIFY THAT THE POLICIES INDICATED. NOTWITHSTANDING ANY REQ CERTIFICATE MAY BE ISSUED OR MAY PE EXCLUSIONS AND CONDITIONS OF SUCH	UIREMEN RTAIN, POLICIES	IT, TERM OR CONDITION OF THE INSURANCE AFFORDED LIMITS SHOWN MAY HAV	F ANY ( D BY TH /E BEEN	CONTRACT OF E POLICIES I REDUCED (	R OTHER DOO DESCRIBED I BY PAID CLAI	CUMENT WITH F HEREIN IS SUBJ	RESPECT	TO WH	ICH THIS
INSR TYPE OF INSURANCE	NDDL SUBR	POLICY NUMBER		(MMDDXYYYY)	(MM/DDYYYYY)		LUMUT	8	
A GENERAL LIABILITY		3762860118EN	þ	03/18/2018	07/20/2018	EACH OCCURREN			0,000
X COMMERCIAL GENERAL LIABILITY			ľ			PREMISES (E8 000	ED urrence)	s300,	000
CLAIMS-MADE X OCCUR			ļ			MED EXP (Any one	person)	s 10,0	
						PERSONAL & ADV	INJURY		0,000
						GENERAL AGGREC			0,000
GEN'L AGGREGATE LIMIT APPLIES PER:						PRODUCTS - COM	P/OP AGG	\$2,00	0,000
X POLICY PRO- LOC							- 4 44=	\$	
C AUTOMOBILE LIABILITY	l	6057360317	1	03/18/2018	03/18/2019	COMBINED SINGLE (Ea accident)	LUMIT	\$1,00	0,000
X ANY AUTO			1		i	BODILY INJURY (P		\$	
ALL OWNED SCHEDULED AUTOS						BODILY INJURY (P		\$	
X HIRED AUTOS X NON-OWNED AUTOS			1			PROPERTY DAMA( (Per accident)	3E	\$	
								\$	
A X UMBRELLA LIAB X OCCUR		3762860118EN	ŀ	03/18/2018	07/20/2018	EACH OCCURREN	CE	\$20,0	00,000
EXCESS LIAB CLAIMS-MADE						AGGREGATE		\$20,0	00,000
DED RETENTION\$	_							\$	
B WORKERS COMPENSATION AND EMPLOYERS' LIABILITY	l	6057318231	ŀ	03/18/2018	03/18/2019	WC STATU- TORY LIMITS	X		
ANY PROPRIETOR/PARTNER/EXECUTIVE ( )	N/A					E.L. EACH ACCIDE			0,000
(Mandatory in NH)	""					E.L. DISEASE - EA			
If yes, describe under DESCRIPTION OF OPERATIONS below	_					E.L. DISEASE - PO	LICY LIMIT	\$1,00	0,000
DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES (Attach ACORD 101, Additional Remarks Schedule, If more space is required)  EVIDENCE OF INSURANCE									
CERTIFICATE HOLDER			CANC	ELLATION					
FOR INFORMATIONAL PURPOSES		SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS.							
				RIZED REPRESE	entative				



#### **Description of Financial Surety**

Prior to commencing operation of the facility, Clean Focus Renewables/Greenskies Renewable Energy will provide a form of surety. The form of surety that is acceptable to the Planning Board will cover the cost of removal in the event the town must remove the installation and remediate the landscape, in an amount and form determined to be reasonable by the Planning Board, but in no event to exceed more than 125 percent of the cost of removal.

In addition, Clean Focus Renewables/Greenskies Renewable Energy will submit a fully inclusive estimate of the costs associated with removal, prepared by a qualified engineer, including an escalator for calculating increased removal costs due to inflation.

CFR typically places the required/approved amount of money into an interest baring financial account, such as a Certificate of Deposit (CD), that would be payable to the requestor, Town of Royalston.



# **Utility Notification**

#### Exhibit C - Generating Facility Expedited/Standard Process Interconnection Application

Contact Information (TYPE or PRIM	<u>\{T})</u> :	Date Prepared: 9/25/2018			
Legal Name and Address of Interconnecting Customer					
Interconnecting Customer: Clean Focus Renewables Inc		Contact Person: Jean-Paul La Marche			
Mailing Address: 363 Centennial Parky	vay Suite 105				
City: Louisville	State: CO	Zip Code: 80027			
Telephone (Daytime): 720 638 6553	0	Evening):			
Facsimile Number:	E	-Mail Address:			
Ownership Information (include % own	nership by any electric util	ty):			
be reviewed by the Massachusetts DG 'Group Study Agreement: "I understand at contact information and project details	Illow information regarding Working Group that is exp and agree if my project becoming with other parties that are	? Yes \( \) No the processing of my application (without my name and address) to loring ways to further expedite future interconnections." \( \) Yes \( \) No mes part of a Group Study, the Company is authorized to share my also involved in the Group Study." \( \) Yes \( \) No different than Interconnecting Customer information above):			
Retail Customer:		Contact Person:			
E-Mail Address:		Telephone:			
Landowner email:  Landowner Mailing Address:  City:	State:	Zip Code:  or or coordinating company, if appropriate):			
A TOTAL CONTRACTOR OF THE PARTY		Contact Person:			
Mailing Address:					
Barto de litera de marca de marca de la composición del composición de la composición de la composición de la composición del composición de la composición del composición de la composición del composición del composición del composición del composición del composición del composic		Zip Code:			
		Evening):			
		-Mail Address:			
	E-	mail Address:			
7.4. A		elephone:			
		Zip Code:			
Interconnection Tariff: "I have reviewe Facility Information (TYPE or PRIN	the entire MDPU 1248 5 (T): corts (either mandatory or	ed Interconnection Seminars." (Recommended) Yes No tandards for Interconnection of DG." (Recommended) Yes No optional as per MDPU 1248) as attachments.			
City: Royalston	State: MA	Zip Code: 01368			
Single Parcel: Will the Facility be cons					
Authorized/Proposed generation capaci	ity already exists (check al ame Legal Parcel of Land	that apply):			
Electric Service Company: National Gr	rid Account Number:	Meter Number:			
Work Request Number (For Upgrades	or New Service):	MTC ID:			
System Design Capacity: Nomina For Solar PV provide the DC-STC ratio		400 (kVA) Maximum 2400 (kW <sub>AC</sub> ) 2400 (kVA)			

Massachusetts: http://www.nationalgridus.com/masselectric/home/energyeff/distributed\_generation.asp Nantucket: http://www.nationalgridus.com/nantucket/home/energyeff/distributed\_generation.asp

#### Exhibit C - Generating Facility Expedited/Standard Process Interconnection Application

Prime Mover:   Photovoltaic □ Reciprocating Engine □ Fuel Cell □ Turbine □ Cell □ Turbine	Other:
Energy Source: Solar Wind Hydro Diesel Natural Gas Fuel Oil	Other:
IEEE 1547.1 (UL 1741) Listed? ☐ Yes ☐ No	
1) Generating Unit Type 1	
Manufacturer: Schneider Electric Model Name and Number: CS2400	Quantity: 1
AC Rating:	
Nominal: <u>2400</u> (kW) <u>2400</u> (kVA) <u>600</u> (AC Volts)  Maximum: (kW) (kVA) (AC Volts)  Single or X	Chron Phase
	Three Phase
Generating Unit Type 2 (if applicable)  Manufacturer:  Madel Name and Number:	Quantitus
Manufacturer:Model Name and Number:	Quantity.
AC Rating: Nominal: (kW) (kVA) (AC Volts)	
Nominal:(kW)(kVA)(AC Volts)  Maximum:(kW)(kVA)(AC Volts)	Three Phase
3) Generating Unit Type 3 (if applicable)	
Manufacturer:Model Name and Number:	Quantity:
AC Rating:	
Nominal: (kW) (kVA) (AC Volts)  Maximum: (kW) (kVA) (AC Volts)	CI DI STATE OF THE
Does this project need an air quality permit from the DEP? Yes No Not Sure	
If "Yes", have you applied for it?	
Planning to Export Power? Yes No Is this a Cogenera	tion Facility? Yes X No
Anticipated Export Power Purchaser:	
Export Form?  Qualifying Facility (QF)  Net Metering  Other (explain):	
Estimated Install Date: Estimated. In-Service Date	o:
Agreement Need By:	
If net metering, please refer to Schedule Z of the Standards for Interconnection of Distributed General off-takers must be a Municipality or other Governmental Entity (as defined in 220 C.M.R. 18.02)	
and sy the same of a maniepathy or other core minerial zinny (as defined in 220 c.m.n. 10.02)	and merejore be certified by the Di G.
Application Process	
Interconnecting Customer Signature:	
"I am opting to forego the Expedited Process. Please review this application under the Sta	ndard Process." Yes 🗌 No
I hereby certify that, to the best of my knowledge, all of the information provided in this a	pplication is true:
The state of the s	Control of the Contro
Signature: Title:	Date:
Please attach any documentation provided by the inverter manufacturer describing the in-	
All Application Materials Received (For Company use only):	
The information provided in this application is complete, all attachments and supplementa	l application materials have been received.
and the application may proceed to the initial/screening review stage of the interconnectio	
Signature: Title:	Date:
Application ID number:	

Massachusetts: <a href="http://www.nationalgridus.com/masselectric/home/energyeff/distributed\_generation.asp">http://www.nationalgridus.com/masselectric/home/energyeff/distributed\_generation.asp</a>
<a href="http://www.nationalgridus.com/nantucket/home/energyeff/distributed\_generation.asp">http://www.nationalgridus.com/nantucket/home/energyeff/distributed\_generation.asp</a>
<a href="http://www.nationalgridus.com/nantucket/home/energyeff/distributed\_generation.asp">http://www.nationalgridus.com/nantucket/home/energyeff/distributed\_generation.asp</a>
<a href="http://www.nationalgridus.com/nantucket/home/energyeff/distributed\_generation.asp">http://www.nationalgridus.com/nantucket/home/energyeff/distributed\_generation.asp</a>
<a href="http://www.nationalgridus.com/nantucket/home/energyeff/distributed\_generation.asp">http://www.nationalgridus.com/nantucket/home/energyeff/distributed\_generation.asp</a>

Information on components of the generating facility that are currently Listed

National Standard

UL 1642, UL 1973 (Q318)

UL 1703

UL1741

UL 1741 SA

#### Exhibit C - Generating Facility Expedited/Standard Process Interconnection Application

CS2400

Stack140

DPS-250

#### Generating Facility Technical Detail

2.

3.

4.

5.6.

Inverter

BESS Battery Stack

DC - DC Converter

Equipment Type Manufacturer Model

1. Photovoltaic Module Neo Solar Power D6M 360 H4A

Schneider Electric

Dynapower Company

Total Number of Generating Units in Facility? 1

Powin Energy

Generator Unit Power Factor Rating: 1 Max Adjustable Leading Power Factor? <sup>0</sup> Max Adjustable Lagging Power Factor? <sup>1</sup> Generator Characteristic Data (for all inverter-based machines) Harmonics Characteristics: Harmonic Distortion <3% at Rated Power Start-up power requirements: Utility voltage required for 5-minute start-up of inverter Generator Characteristic Data (for all rotating machines) Rotating Frequency: \_\_\_\_\_ (rpm) Neutral Grounding Resistor (If Applicable): Additional Information for Synchronous Generating Units (PU) Synchronous Reactance, Xd: (PU) Transient Reactance, X'd: \_(PU) (PU) Neg Sequence Reactance, X2: Subtransient Reactance, X"d: \_ (PU) kVA Base: \_(PU) Zero Sequence Reactance, Xo: (Volts) Field Current: (Amps) Field Voltage: Additional information for Induction Generating Units Rotor Resistance, Rr: Stator Resistance, Rs: Stator Reactance, Xs: Rotor Reactance, Xr: Short Circuit Reactance, Xd": Magnetizing Reactance, Xm: **Exciting Current:** Temperature Rise: Frame Size: Per Unit on kVA Base: Total Rotating Inertia, H: Reactive Power Required In Vars (No Load):

(kW) Design Letter:

Massachusetts: <a href="http://www.nationalgridus.com/masselectric/home/energyeff/distributed\_generation.asp">http://www.nationalgridus.com/masselectric/home/energyeff/distributed\_generation.asp</a>
<a href="http://www.nationalgridus.com/nantucket/home/energyeff/distributed\_generation.asp">http://www.nationalgridus.com/nantucket/home/energyeff/distributed\_generation.asp</a>

Additional information for Induction Generating Units that are started by motoring

Reactive Power Required In Vars (Full Load):

Motoring Power:

#### Exhibit C - Generating Facility Expedited/Standard Process Interconnection Application

Interconnection Equipment						
Will a transformer be used between the generator and the point of interconnection?						
Will the transformer be provided by Interconnecting Customer?						
Transformer Data (if applicabl	e, for Interconnecting	Customer-Owned Transf	former):			
Nameplate Rating:	<u>2400</u> (kVA)		☐ Single or ▷	Three Phase		
Transformer Impedance:	<u>5.75</u> (%) on a	2400	kVA Base			
If Three Phase:  Transformer Primary:  Transformer Secondary:  Transformer Secondary:	600 (Volts) X	Delta Wye Wye-	-Grounded 🔲 (			
Transformer Fuse Data (if app						
(Attach copy of fuse manufact						
Manufacturer: TBD	Type: <u>TBD</u>	Siz	ze: TBD	Speed: TBD		
Interconnecting Circuit Breake						
Manufacturer: Cooper	Type: Recl	oser Lo	ad Rating: 600	(Amps)		
Interrupting Rating: 600	Trip Speed	:(Cy	(cles)			
Interconnection Protective Rel	ays (if applicable):					
If microprocessor-controlled, l	List of Functions and A	Adjustable Setpoints for t	he protective ec	quipment or software		
Setpoi	nt Function	Min	nimum	Maximum		
1. Voltage		< 6900V -		>=16560V		
2. Frequency		F > 60.5 HZ		F < 58.0Hz		
3. Current		TBD		TBD		
4.						
5.		1111		2		
6.	1: 11			-		
If discrete components (Enclos	se copy of any propose	d Time-Overcurrent Coo	ordination Curve	es):		
Manufacturer:	Type:	Style/Catalog No.:	Pr	oposed Setting:		
Manufacturer:	Type:	Style/Catalog No.:	Pr	oposed Setting:		
Manufacturer:						
Manufacturer:						
Manufacturer:						
Manufacturer:						
Current Transformer Data (if a						
(Enclose copy of Manufacture	r's Excitation & Ratio	Correction Curves)				
Manufacturer:TBD		SCOTO SCOTO CON CONTRACTOR CONTRA	.3% Propose	d Ratio Connection:	250/5	
Manufacturer: TBD	- 5 5.10. Ster-			d Ratio Connection:	12700000000	
Potential Transformer Data (if		- II				
Manufacturer: TBD	A DE TRANSPORTE DE TRANSPORTE DE LA CONTRACTION DEL CONTRACTION DE LA CONTRACTION DE	Accuracy Class: _0	.3% Propose	d Ratio Connection:	115:1	
Manufacturer:	Type:	Accuracy Class:	Propose	d Ratio Connection:		

 $\label{lem:massachusetts:http://www.nationalgridus.com/masselectric/home/energyeff/distributed\_generation.asp\\ Nantucket: \\ \underline{\text{http://www.nationalgridus.com/nantucket/home/energyeff/distributed\_generation.asp}\\$ 


#### Exhibit C - Generating Facility Expedited/Standard Process Interconnection Application


General Technical Details
Submit all of the customer's Interconnection Application materials and proposed design diagrams using the following process:
1. Email the following materials to National Grid at <u>Distributed.Generation@nationalgrid.com</u> :
a. P.Estamped One-Line Diagram (and Three-Line Diagram if applicable), including:
<ul> <li>i. Schematics for all (internal &amp; redundant) protection and control circuits, relay current circuits relay potential circuits, and alarm/monitoring circuits (if applicable)</li> </ul>
b.  Site Plan, which indicates the precise physical location of the proposed:
i. Generating Facility
ii. AC Utility Disconnect Switch
iii.  All meters (utility- and customer-owned)
iv. Related interconnection equipment
c. Technical Specifications (pdf files only)
<ul> <li>d.  Exhibit C (this form) – completed and signed (available on the website)</li> </ul>
e.    Legal Information Document – completed (available on the website)
f. Schedule Z (net metering only) - completed, initialed, and signed (available on the website)
g. Copy of electric bill (if applicable)
h. Copy of any Pre-Application Reports related to this application (if applicable)
i. Copy of Interconnection Application fee check
j. Any other information pertinent to this Interconnection Application (if applicable)
<ol> <li>Mail the  Interconnection Application fee check and the  first two pages of the signed copy of this Interconnection Application form to:</li> </ol>
National Grid Attn: Distributed Generation 40 Sylvan Rd Waltham, MA 02451
Note: The Schedule Z may be updated as needed at any point prior to the Authorization to Interconnect.
Refer to National Grid's Distributed Generation website for more detailed instructions:
Massachusetts:
Residential: <a href="http://www.nationalgridus.com/masselectric/home/energyeff/distributed_generation.asp">http://www.nationalgridus.com/masselectric/home/energyeff/distributed_generation.asp</a>
Commercial: http://www.nationalgridus.com/masselectric/business/energyeff/distributed_generation.asp
Nantucket:
Residential: <a href="http://www.nationalgridus.com/nantucket/home/energyeff/distributed_generation.asp">http://www.nationalgridus.com/nantucket/home/energyeff/distributed_generation.asp</a>
Commercial: http://www.nationalgridus.com/nantucket/business/energyeff/distributed_generation.asp


Massachusetts: http://www.nationalgridus.com/masselectric/home/energyeff/distributed\_generation.asp Nantucket: http://www.nationalgridus.com/nantucket/home/energyeff/distributed\_generation.asp



## **Electrical Drawings**








20 A 15 A

20 A 15 A



AC SINGLE-LINE DIAGRAM SCALE: N.T.S.

SHEET NOTES:

1. OVERCURRENT SETTINGS TO BE CONFIRMED BY COORDINATION STUDY DURING DETAIL DESIGN.

2. TRANSFORMER VENDOR TO SPECIFY QUANTITY AND TYPE OF FUSES.

3. CONTRACTOR TO SUBMIT ALL EQUIPMENT FOR EOR REVIEW

AND APPROVAL. 4. INVERTER TO BE SET TO THE FOLLOWING SETTINGS:

	DEVICE NO.	PICKUP	MAX CLEARING TIME (SEC)
	27-1	V < 300V	0.16
		(50%)	
	27-2	$300V \le V \le 528V$	2.0
VOLTAGE	27-2	(50% ≤ V ≤ 88%)	2.0
	59-1	660V < V < 720V	1.0
		(110% < V < 120%)	1.0
	59-2	V ≥ 720V	0.16
		(V ≥ 120%)	0.16
	810-1	F ≥ 61.8HZ	0.16
FREQUENCY	81U-1	F ≤ 57.8HZ	0.16
	81U-2	F ≤ 59.5HZ	32
•		•	•

5. RELAY TO BE SET TO THE FOLLOWING SETTINGS:

RELAY DEVICE TABLE						
	DEVICE NO.	PICKUP	MAX CLEARING TIME (SEC			
VOLTAGE	27-1	< 6900V (50%)	0.16			
	27-2	6900V ≤ V < 12144V (50% ≤ V< 88%)	2.0			
	59-1	15180V < V < 16560V 110% < V < 120%	1.0			
	59-2	16560V ≥ (120% ≥)	0.16			
	810-1	F > 60.5HZ	0.16			
FREQUENCY	81U-1	F < 57.0HZ	0.16			
	81U-2	F < 58.0HZ	32			
	50	TBD	TBD			
CURRENT	51	TBD	TBD			
	51C	TBD	TBD			
	51G	TBD	TBD			

6. RELAY TO BE EQUIPPED WITH TWO TEST SWITCHES; 1 FOR VOLTAGE AND CURRENTS (ABB FT-1 STYLE NO. C188A523G01), 2 FOR DC INPUTS AND OUTPUTS (ABB FT-1 STYLE NO. 129A501G01).

7. PV CIRCUIT BREAKER TO BE UTILITY LOCKABLE DISCONNECT, BREAKER TO BE RACKABLE.

#### SYMBOL LEGEND

FCI

(1)

 $\rightarrow$   $\leftarrow$ 

STINIBUL LEGEND	
	TRANSFORMER
~	DC-AC INVERTER
<b>51</b>	RELAY COMPONENT
———	FUSE
0_0	SWITCH
M	MOTORIZED SWITCH
$\prec$ °	GANG-OPERATED SWITCH
	VACUUM BREAKER
-0 0-	LOW VOLTAGE CIRCUIT BREAKER
<b>—</b>	UNDERGROUND CABLE TERMINATION
=	GROUND
	SURGE ARRESTER

PHOTOVOLTAIC MODULE FAULTED CIRCUIT INDICATOR CONDUIT OR CABLE NUMBER CURRENT TRANSFORMER POTENTIAL TRANSFORMER


CURRENT TEST SWITCH

POTENTIAL TEST SWITCH

REVAMP

555 12th St, 5th Floor Oakland, CA 94607 www.revamp-eng.com

THIS DOCUMENT IS THE PROPERTY OF REVAMP ENGINEERING, INC., AND CONTAINS CONFIDENTIAL INFORMATION. ITS RECEIPT OR POSSESSION DOES NOT CONVEY ANY RIGHTS TO REPRODUCE, MANUFACTURE, USE, OR SELL ANYTHING IT MAY DESCRIBE. NO PART IS TO BE DISCLOSED WITHOUT WRITTEN PERMISSION FROM REVAMP ENGINEERING, INC. **ENGINEER'S STAMP** 



CLIENT



SOL 4 BEL NEL FON, WA OIS ∞ 4 KING ST 8 ROYALS

ROY,

DRAWING ISSUE 09/17/2018 PRELIMINARY 09/28/2018 2 ISSUE FOR REVIEW

**REVISION ISSUE** 

DRAWN BY:TR CHECKED BY:MH **PROJECT NO.**: 18116 DRAWING TITLE **AC SINGLE-LINE** 

DIAGRAM

DRAWING NUMBER

REVAMP ENGINEERING, INC.

> 555 12th St, 5th Floor Oakland, CA 94607

www.revamp-eng.com

THIS DOCUMENT IS THE PROPERTY OF REVAMP ENGINEERING, INC., AND CONTAINS CONFIDENTIAL INFORMATION ITS RECEIPT OR POSSESSION DOES NOT CONVEY ANY RIGHTS TO REPRODUCE, MANUFACTURE, USE, OR SELL ANYTHING IT MAY DESCRIBE. NO PART IS TO BE DISCLOSED WITHOUT WRITTEN PERMISSION FROM REVAMP ENGINEERING, INC. **ENGINEER'S STAMP** 



CLIENT



4 KING ST & 4 BEL NEL ROAD ROYALSTON, MA 01368

SOL ROY,

SYMBOL LEGEND

TRANSFORMER

DC-AC INVERTER

RELAY COMPONENT

MOTORIZED SWITCH

GANG-OPERATED

VACUUM BREAKER

UNDERGROUND CABLE

LOW VOLTAGE CIRCUIT BREAKER

TERMINATION

SURGE ARRESTER

PHOTOVOLTAIC MODULE

FAULTED CIRCUIT INDICATOR

CONDUIT OR CABLE NUMBER

CURRENT TRANSFORMER

POTENTIAL TRANSFORMER

CURRENT TEST SWITCH

POTENTIAL TEST SWITCH

GROUND

**FUSE** 

SWITCH

SWITCH

 $\frac{\omega}{m}$ 

(51)

 $-\!\Box\!\!\!\!\!-$ 

о<u>~</u>°

 $\equiv$ 

FCI

 $\bigcirc M \bigcirc \bigcirc$ 

DRAWING ISSUE 09/17/2018 PRELIMINARY

O

2 ISSUE FOR REVIEW

09/28/2018

**REVISION ISSUE** 

DRAWN BY:TR CHECKED BY:MH **PROJECT NO.**: 18116

DRAWING TITLE THREE LINE

DIAGRAM

DRAWING NUMBER

THREE LINE DIAGRAM SCALE: N.T.S.

400/5

450/5

500/5

600/5


X1-X4

X3-X5

X2-X5

X1-X5

- INDICATES CUSTOMER USE TERMINAL POINT




NOTES: ALL WIRING TO BE #12, UNLESS OTHERWISE NOTED. LEGEND: SEL-300G-P - PRIMARY FEEDER PROTECTION RELAY

CONTROL DIAGRAM
SCALE: N.T.S.

REVAMP ENGINEERING, INC.

> 555 12th St, 5th Floor Oakland, CA 94607 www.revamp-eng.com

THIS DOCUMENT IS THE PROPERTY OF REVAMP ENGINEERING, INC., AND CONTAINS CONFIDENTIAL INFORMATION. ITS RECEIPT OR POSSESSION DOES NOT CONVEY ANY RIGHTS TO REPRODUCE, MANUFACTURE, USE, OR SELL ANYTHING IT MAY DESCRIBE. NO PART IS TO BE DISCLOSED WITHOUT WRITTEN PERMISSION FROM REVAMP ENGINEERING, INC. ENGINEER'S STAMP



CLIENT



CLEAN F CUS

4 KING ST & 4 BEL NEL ROAD ROYALSTON, MA 01368

# SOL ROYAL

DRAWING ISSUE 09/17/2018 PRELIMINARY

**REVISION ISSUE** 

2 09/28/2018 ISSUE FOR REVIEW

DRAWN BY:TR CHECKED BY:MH

**PROJECT NO.**: 18116

**DIAGRAM 1** 

DRAWING NUMBER

DRAWING TITLE CONTROL

LOW VOLTAGE CIRCUIT BREAKER UNDERGROUND CABLE TERMINATION

O

GROUND

SURGE ARRESTER

TRANSFORMER

DC-AC INVERTER

RELAY COMPONENT

MOTORIZED SWITCH

GANG-OPERATED

VACUUM BREAKER


FUSE

SWITCH

SWITCH

PHOTOVOLTAIC MODULE

FAULTED CIRCUIT INDICATOR



CONDUIT OR CABLE NUMBER



SYMBOL LEGEND

(51)

 $-\!\!\!\square\!\!\!-\!\!\!\!\square$ 

 $\sim$ 

M

**—** 

 $\equiv$ 


CURRENT TRANSFORMER

POTENTIAL TRANSFORMER

$\rightarrow$ $\leftarrow$	
X	

CURRENT TEST SWITCH


CORRENT TEST SWITCH
POTENTIAL TEST SWITCH



REVAMP ENGINEERING, INC.

> 555 12th St, 5th Floor Oakland, CA 94607 www.revamp-eng.com

THIS DOCUMENT IS THE PROPERTY OF REVAMP ENGINEERING, INC., AND CONTAINS CONFIDENTIAL INFORMATION. ITS RECEIPT OR POSSESSION DOES NOT CONVEY ANY RIGHTS TO REPRODUCE, MANUFACTURE, USE, OR SELL ANYTHING IT MAY DESCRIBE. NO PART IS TO BE DISCLOSED WITHOUT WRITTEN PERMISSION FROM REVAMP ENGINEERING, INC. **ENGINEER'S STAMP** 



CLIENT



SOL

T & 4 BEL NEL ROAD LSTON, MA 01368

4 KING ST ROYALS

**DRAWING ISSUE** 09/17/2018 PRELIMINARY

O

2 09/28/2018 ISSUE FOR REVIEW

**REVISION ISSUE** 

DRAWN BY:TR CHECKED BY:MH

**PROJECT NO.**: 18116 DRAWING TITLE

CONTROL DIAGRAM 2

DRAWING NUMBER



SHEET NOTES:

1. LOCATIONS SHOWN ARE FOR GENERAL GUIDANCE ONLY. SLOPES OF THE SITE ARE NOT DEPICTED AND LOCATIONS MUST BE VERIFIED ON SITE BEFORE INSTALLATION.

#### SYSTEM SPECIFICATIONS:

SYSTEM SPECIFICATIONS:	
SYSTEM STC DC RATING (kW)	3110
SYSTEM AC CAPACITY (kW)	2400
SYSTEM AC CAPACITY (kVA)	2400
DC/AC RATIO AT POI	1.30
MODULE MODEL	NSP 360W
MODULE STC DC RATING (W)	360
MODULE COUNT	8640
MODULES PER STRING	27
STRING COUNT	320
2 STRING TABLE	160
1 STRING TABLE	0
INVERTER MODEL	SCHNEIDER ELECTRIC CS2400
INVERTER RATING (kW)	2400
QUANTITY OF INVERTERS	1
TRANSFORMER RATING (kVA)	2400
QUANTITY OF TRANSFORMERS	1
DC SYSTEM VOLTAGE (V)	1500
SYSTEM DC CAPACITY (kW) FOR BESS	1000
SYSTEM ENERGY STORAGE (kWh)	2100
BESS BATTERY STACK MODEL	POWIN ENERGY STACK 140
BESS BATTERY STACK NOMINAL ENERGY	
CAPACITY (kWh)	140
BESS BATTERY STACKS PER CONTAINER	15
QUANTITY OF BESS CONTAINERS	1
DC-DC CONVERTER MODEL	DYNAPOWER DPS-250
DC-DC CONVERTER RATING (kW)	250
QUANTITY OF DC-DC CONVERTERS	4
NOMINAL USEFUL ENERGY CAPACITY (HRS)	2.10
NOMINAL RATED POWER CAPACITY OF BESS (%)	32.2%
INTERCONNECTION VOLTAGE (KV)	13.8
RACKING SYSTEM	FIXED TILT (2X10 PORTRAIT)
MODULE TILT	30°
AZIMUTH	180°
GCR	0.43
ROW-TO-ROW SPACING (LF, PROJECTED)	26.25
ASHRAE 2% DESIGN BULB TEMP MAX (°C)	29°
ASHRAE EXTREME ANNUAL MEAN MINIMUM DRY- BULB TEMP	-20°
PROPERTY AREA (ACRES)	15
FENCED AREA (ACRES)	12
FENCING LENGTH (L.F.)	2821
ROADS (L.F.)	984

<u>LEGEND</u>	
	PROPERTY LINE
x x x	FENCE LINE
	ROAD
— O/H — O/H —	OVERHEAD ELECTRICAL
	SETBACK / WATERS
	RIGHT OF WAY (ROW)

WETLANDS SHADE SETBACK

CLIENT

ENGINEERING, INC.

555 12th St, 5th Floor

Oakland, CA 94607

www.revamp-eng.com

THIS DOCUMENT IS THE PROPERTY OF REVAMP ENGINEERING, INC., AND

CONTAINS CONFIDENTIAL INFORMATION. ITS RECEIPT OR POSSESSION DOES NOT

CONVEY ANY RIGHTS TO REPRODUCE, MANUFACTURE, USE, OR SELL ANYTHING IT MAY DESCRIBE. NO PART IS TO BE DISCLOSED WITHOUT WRITTEN PERMISSION

FROM REVAMP ENGINEERING, INC.

ELECTRICAL

**ENGINEER'S STAMP** 

ROYAL

DRAWING ISSUE 1 09/17/2018 1 PRELIMINARY 09/28/2018 2 ISSUE FOR REVIEW **REVISION ISSUE** 

DRAWN BY:TR CHECKED BY:MH

PROJECT NO.: 18116

DRAWING TITLE

OVERALL SITE

LAYOUT

DRAWING NUMBER